

BRL-K664

2020-04-07

Evaluation Guideline

for the Kiwa product certificate for
Semi-rigid hose for fire hose reels in fixed
Firefighting systems



**Trust
Quality
Progress**

Preface

This evaluation guideline has been accepted by the Kiwa Board of Experts Watercycle (CWK), in which all relevant parties in the field of drinking water appliances are represented. The Board of Experts also supervises the certification activities and where necessary requires the evaluation guideline to be revised. All references to Board of Experts in this evaluation guideline pertain to the above mentioned Board of Experts.

This evaluation guideline will be used by Kiwa in conjunction with the Kiwa Regulations for Certification.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.com

© 2020 Kiwa N.V.

All rights reserved. No part of this report may be reproduced, stored in a database or retrieval system, or published, in any form or in any way, electronically, mechanically, by print, photoprint, microfilm or any other means without prior written permission from the publisher.

The use of this evaluation guideline by third parties, for any purpose whatsoever, is only allowed after a written agreement is made with Kiwa to this end.

Binding declaration

This evaluation guideline has been declared binding by Kiwa on 7 April 2020.

Contents

1	Introduction	4
1.1	General	4
1.2	Field of application / scope	4
1.3	Acceptance of test reports provided by the supplier	4
1.4	Quality declaration	4
2	Terms and definitions	5
2.1	Definitions	5
3	Procedure for granting a product certificate	6
3.1	Initial investigation	6
3.2	Granting the product certificate	6
3.3	Investigation into the product and/or performance requirements	6
3.4	Production process assessment	6
3.5	Contract assessment	6
4	Requirements	7
4.1	General	7
4.2	Product requirements	7
4.3	Deviating requirements	7
4.4	Additional product requirements	7
5	Marking	8
5.1	General	8
5.2	Certification mark	8
6	Requirements in respect of the quality system	9
6.1	Manager of the quality system	9
6.2	Internal quality control/quality plan	9
6.3	Control of test and measuring equipment	9
6.4	Procedures and working instructions	9
6.5	Other requirements	9
7	Summary of tests and inspections	10
7.1	Test matrix	10
7.2	Inspection of the quality system of the supplier	11
8	Agreements on the implementation of certification	12

8.1	General	12
8.2	Certification staff	12
8.3	Report initial investigation	13
8.4	Decision for granting the certificate	14
8.5	Layout of quality declaration	14
8.6	Nature and frequency of third party audits	14
8.7	Non conformities	14
8.8	Report to the Board of Experts	15
9	Titles of standards	16
9.1	Public law rules	16
9.2	Standards / normative documents	16
I	Model certificate (example)	17
II	Model IQC-scheme (example)	18

1 Introduction

1.1 General

This evaluation guideline includes all relevant requirements which are employed by Kiwa when dealing with applications for the issue and maintenance of a certificate for "semi-rigid hose for fire hose reels in fixed firefighting systems".

This guideline replaces the evaluation guideline BRL-K664/02, dated 01-02-2012. The quality declarations issued and based on that guideline will lose their validity at least 2 years after validation of this BRL.

For the performance of its certification work, Kiwa is bound to the requirements as included in NEN-EN-ISO/IEC 17065 "Conformity assessment - Requirements for bodies certifying products, processes and services".

1.2 Field of application / scope

The semi-rigid hoses have been designed to be used on fire hose reels conform the Kiwa evaluation guideline BRL-K643 "Fixed firefighting systems. Hose systems: hose reels with semi-rigid hose". These hose reels can be connected to drinking water installations with a maximum water pressure of 1000 kPa and a water temperature of maximum 30°C.

1.3 Acceptance of test reports provided by the supplier

If the supplier provides reports from test institutions or laboratories to prove that the products meet the requirements of this evaluation guideline, the supplier shall prove that these reports have been drawn up by an institution that complies with the applicable accreditation standards, namely:

- NEN-EN-ISO/IEC 17020 for inspection bodies;
- NEN-EN-ISO/IEC 17021-1 for certification bodies certifying systems;
- NEN-EN-ISO/IEC 17024 for certification bodies certifying persons;
- NEN-EN-ISO/IEC 17025 for laboratories;
- NEN-EN-ISO/IEC 17065 for certification bodies certifying products.

Remark:

This requirement is considered to be fulfilled when a certificate of accreditation can be shown, issued either by the Board of Accreditation (RvA) or by one of the institutions with which an agreement of mutual acceptance has been concluded by the RvA. The accreditation shall refer to the examinations as required in this evaluation guideline. When no certificate of accreditation can be shown, Kiwa shall verify whether the accreditation standard is fulfilled.

1.4 Quality declaration

The quality declaration to be issued by Kiwa is described as a Kiwa product certificate.

A model of the certificate to be issued on the basis of this evaluation guideline has been included for information as Annex.

2 Terms and definitions

2.1 Definitions

In this evaluation guideline, the following terms and definitions apply:

- **Board of Experts:** the Board of Experts Watercycle (CWK).
- **Certification mark:** a protected trademark of which the authorization of the use is granted by Kiwa, to the supplier whose products can be considered to comply on delivery with the applicable requirements and possibly with quality information on the application of the product is added by a specially designed label which is based on the result, as stated in the report issued by Kiwa on the inspection of the prototype
- **Drinking water installation:** an installation direct or in-direct connected to the public drinking water distribution network of a drinking water company (source Dutch drinking water act);
- **Evaluation Guideline (BRL):** the agreements made within the Board of Experts on the subject of certification.
- **Installation:** configuration consisting the pipe work, fittings and appliances;
- **Inspection tests:** tests carried out after the certificate has been granted in order to ascertain whether the certified products continue to meet the requirements recorded in the evaluation guideline.
- **IQC scheme (IQCS):** a description of the quality inspections carried out by the supplier as part of his quality system.
- **Initial investigation:** tests in order to ascertain that all the requirements recorded in the evaluation guideline are met.
- **Private Label Certificate:** A certificate that only pertains to products that are also included in the certificate of a supplier that has been certified by Kiwa, the only difference being that the products and product information of the private label holder bear a brand name that belongs to the private label holder.
- **Product certificate:** a document in which Kiwa declares that a product may, on delivery, be deemed to comply with the product specification recorded in the product certificate.
- **Product requirements:** requirements made specific by means of measures or figures, focussing on (identifiable) characteristics of products and containing a limiting value to be achieved, which can be calculated or measured in an unequivocal manner.
- **Supplier:** the party that is responsible for ensuring that the products meet and continue to meet the requirements on which the certification is based.

3 Procedure for granting a product certificate

3.1 Initial investigation

The initial investigation to be performed are based on the (product) requirements as contained in this evaluation guideline, including the test methods, and comprises the following:

- type testing to determine whether the products comply with the product and/or functional requirements;
- production process assessment;
- assessment of the quality system and the IQC-scheme;
- assessment on the presence and functioning of the remaining procedures.

3.2 Granting the product certificate

After finishing the initial investigation, the results are presented to the Decision maker (see 9.2) deciding on granting the certificate. This person evaluates the results and decides whether the certificate can be granted or if additional data and/or tests are necessary.

3.3 Investigation into the product and/or performance requirements

Kiwa will investigate the to be certified products against the certification requirements as stated in the certification requirements.

The necessary samples will be drawn by or on behalf of Kiwa.

3.4 Production process assessment

When assessing the production process, it is investigated whether the producer is capable of continuously producing products that meet the certification requirements.

The evaluation of the production process takes place during the ongoing work at the producer.

The assessment also includes at least:

- The quality of raw materials, half-finished products and end products;
- Internal transport and storage.

3.5 Contract assessment

If the supplier is not the producer of the products to be certified, Kiwa will assess the agreement between the supplier and the producer.

This written agreement, which is available for Kiwa, includes at least:

- Accreditation bodies, scheme managers and Kiwa will be given the opportunity to observe the certification activities carried out by Kiwa or on behalf of Kiwa at the producer.

4 Requirements

4.1 General

This chapter contains the requirements that semi-rigid hose for fire hose reels in fixed firefighting systems have to fulfil.

4.2 Product requirements

The requirements of the product are specified in the following standard, with the exception to what is mentioned in clauses 4.3 and 4.4, have been established in the following standard:

EN 694	Fire-fighting hoses - Semi-rigid hoses for fixed systems
--------	--

4.3 Additional product requirements

In addition to the requirements mentioned in section 4.2, the following applies.

4.3.1 Composition

The manufacturer shall submit to the certifying body data about the raw material of which the hoses have been manufactured.

4.4 Deviating requirements

In contradiction to the requirements as mentioned in 4.2 the following applies.

4.4.1 Watertightness

In contradiction to what has been mentioned in EN 694, the semi-rigid hose with a nominal diameter of 33 mm shall be suitable for application with pressures up to 1000 kPa. Therefore, with the examination in accordance with article 6.1.2 of the EN 694, the concerning hose shall show no leakage with pressures up to 2000 kPa and shall not burst with pressures up to 3500 kPa.

5 Marking

5.1 General

In addition to the marking as specified in clause 8 of the EN 694, the hose may be marked with the name or logo of the manufacturer of the fire hose reel on which the hose is used.

In contradiction to what has been mentioned in clause 8 of the EN 694 the hose shall be marked each 5 meter.

Remark

Due to the fact the hose to be used influences the functioning of the fire hose reel, there shall be guaranteed that only hoses will be used which have been tested as a part of the fire hose reel. Therefore the hose shall be marked according to the requirements included in the Kiwa evaluation guideline BRL-K643.

5.2 Certification mark

After concluding a Kiwa certification agreement the certified products shall be indelible marked with the wordmark "KIWA".

6 Requirements in respect of the quality system

This chapter contains the requirements which have to be met by the supplier's quality system.

6.1 Manager of the quality system

Within the supplier's organizational structure, an employee who will be in charge of managing the supplier's quality system must have been appointed.

6.2 Internal quality control/quality plan

The supplier shall have an internal quality control scheme (IQC scheme) which is applied by him.

The following must be demonstrably recorded in this IQC scheme:

- which aspects are checked by the supplier;
- according to what methods such inspections are carried out;
- how often these inspections are carried out;
- in what way the inspection results are recorded and kept.

This IQC scheme should at least be an equivalent derivative of the model IQC scheme as shown in the Annex.

6.3 Control of test and measuring equipment

The supplier shall verify the availability of necessary test and measuring equipment for demonstrating product conformity with the requirements in this evaluation guideline.

When required the equipment shall be kept calibrated (e.g recalibration at interval).

The status of actual calibration of each equipment shall be demonstrated by traceability through an unique ID.

The supplier must keep records of the calibration results.

The supplier shall review the validity of measuring data when it is established at calibration that the equipment is not suitable anymore.

6.4 Procedures and working instructions

The supplier shall be able to submit the following:

- procedures for:
 - dealing with products showing deviations;
 - corrective actions to be taken if non-conformities are found;
 - dealing with complaints about products and/or services delivered;
- the working instructions and inspection forms used.

6.5 Other requirements

The supplier shall be able to submit the following:

- the organisation's organogram;
- qualification requirements of the personnel concerned.

7 Summary of tests and inspections

This chapter contains a summary of the following tests and inspections to be carried out in the event of certification:

- **initial investigation:** tests in order to ascertain that all the requirements recorded in the evaluation guideline are met;
- **inspection test:** tests carried out after the certificate has been granted in order to ascertain whether the certified products continue to meet the requirements recorded in the evaluation guideline;
- **inspection of the quality system of the supplier:** monitoring compliance of the IQC scheme and procedures.

7.1 Test matrix

Description of requirement	Article no. of BRL	Tests within the scope of:		
		Pre-certification	Inspection by Kiwa after granting of certificate ^{a,b)}	
			Inspection	Frequently (# / year)
Product requirements				
EN 694				
Inside diameter	5.1	X	X	batch
Maximum mass	5.1	X	X	batch
Functional requirements				
Deformation under maximum working pressure	6.1.1	X	X	batch
Deformation under proof pressure	6.1.2	X	X	batch
Minimum burst pressure	6.1.3	X	X	batch
Kink pressure	6.1.4	X	X	batch
Adhesion	6.2	X	X	batch
Accelerated aging	6.3	X	X	1/3
Low temperature flexibility	6.4	X	X	1/3
Hot surface resistance	6.5	X	X	1/3
Ozone resistance	6.6	X		
Banding and crush resistance	6.7	X	X	1
UV-resistance	6.8	X		
Loss on mass on heating	6.9	X	X	1
Marking	8	X	X	2
Additional requirements				
BRL-K664				
Composition	4.3.1	X	X	2
Deviating requirements				
BRL-K664				

Description of requirement	Article no. of BRL	Tests within the scope of:		
		Pre-certification	Inspection by Kiwa after granting of certificate ^{a,b)}	
			Inspection	Frequently (# / year)
Watertightness	4.4.1	X	X	1/3
Certification mark	5	X	X	2

- a) In case the product or production process changes, it must be determined whether the performance requirements are still met.
- b) During the inspection tests, the inspector verifies the products on basis of a selection from the above mentioned product requirements. The frequency of inspection visits is defined in chapter 8.6 of this evaluation guideline.

7.2 Inspection of the quality system of the supplier

The quality system of the supplier will be checked by Kiwa on the basis of the IQC scheme.

The inspection contains at least those aspects mentioned in Article 6 of this BRL.

8 Agreements on the implementation of certification

8.1 General

Beside the requirements included in these evaluation guidelines, the general rules for certification as included in the Kiwa Regulations for Product Certification also apply. These rules are in particular:

- the general rules for conducting the pre-certification tests, in particular:
 - the way suppliers are to be informed about how an application is being handled;
 - how the test are conducted;
 - the decision to be taken as a result of the pre-certification tests.
- the general rules for conducting inspections and the aspects to be audited,
- the measures to be taken by Kiwa in case of Non-Conformities,
- the measures taken by Kiwa in case of improper use of Certificates, Certification Marks, Pictograms and Logos,
- terms for termination of the certificate,
- the possibility to lodge an appeal against decisions of measures taken by Kiwa.

8.2 Certification staff

The staff involved in the certification may be sub-divided into:

- Certification assessor (**CAS**): in charge of carrying out the pre-certification tests and assessing the inspectors' reports;
- Site assessor (**SAS**): in charge of carrying out external inspections at the supplier's works;
- Decision maker (**DM**): in charge of taking decisions in connection with the pre-certification tests carried out, continuing the certification in connection with the inspections carried out and taking decisions on the need to take corrective actions.

8.2.1 Qualification requirements

The qualification requirements consist of:

- qualification requirements for personnel of a certification body which satisfies the requirements EN ISO / IEC 17065, performing certification activities
- qualification requirements for personnel of a certification body performing certification activities set by the Board of Experts for the subject matter of this evaluation guideline

Education and experience of the concerning certification personnel shall be recorded demonstrably.

Basic requirements	Evaluation criteria
Knowledge of company processes Requirements for conducting professional audits on products, processes, services, installations, design and management systems.	<i>Relevant experience: in the field</i> SAS, CAS : 1 year DM : 5 years inclusive 1 year with respect to certification Relevant technical knowledge and experience on the level of: SAS : High school CAS, DM : Bachelor

Basic requirements	Evaluation criteria
Competence for execution of site assessments. Adequate communication skills (e.g. reports, presentation skills and interviewing technique).	SAS: Kiwa Audit training or similar and 4 site assessments including 1 autonomic under review.
Execution of initial examination	CAS: 3 initial audits under review.
Conducting review	CAS: conducting 3 reviews

Technical competences	Evaluation Criteria
Education	General: Education in one of the following technical areas: <ul style="list-style-type: none"> • Civil Engineering; • Engineering.
Testing skills	General: <ul style="list-style-type: none"> • 1 week laboratory training (general and scheme specific) including measuring techniques and performing tests under supervision ; • Conducting tests (per scheme).
Experience - specific	CAS <ul style="list-style-type: none"> • 2 complete applications (excluding the initial assessment of the production site) under the direction of the CAS • 1 initial assessments of the production site under the direction of the PM • 1 initial assessment of the production site self-reliant (witnessed by PM) SAS <ul style="list-style-type: none"> • 3 inspection visits together with a qualified SAS • 2 inspection visits conducted self-reliant (witnessed by PM)
Skills in performing witnessing	PM Internal training witness testing

Legenda:

- Certification assessor (**CAS**)
- Decision maker (**DM**)
- Product manager (**PM**)
- Site assessor (**SAS**)

8.2.2 Qualification

The qualification of the Certification staff shall be demonstrated by means of assessing the education and experience to the above mentioned requirements. In case staff is to be qualified on the basis of deflecting criteria, written records shall be kept.

The authority to qualify staff rests with the:

- **PM:** qualification of **CAS** and **SAS**;
- management of the certification body: qualification of **DM**.

8.3 Report initial investigation

The certification body records the results of the initial investigation in a report.

This report shall comply with the following requirements:

- completeness: the report provides a verdict about all requirements included in the evaluation guideline;

- traceability: the findings on which the verdicts have been based shall be recorded and traceable;
- basis for decision: the **DM** shall be able to base his decision on the findings included in the report.

8.4 Decision for granting the certificate

The decision for granting the certificate shall be made by a qualified Decision maker which has not been involved in the pre-certification tests. The decision shall be recorded in a traceable manner.

8.5 Layout of quality declaration

The product certificate shall be in accordance with the model included in the Annex.

8.6 Nature and frequency of third party audits

The certification body shall carry out surveillance audits on site at the supplier at regular intervals to check whether the supplier complies with his obligations. The Board of Experts decides on the frequency of audits.

At the time this BRL entered into force, the frequency of audits amounts 2 audit(s) on site per year for suppliers with a quality management system in accordance with ISO 9001 for their production, which has been certified by an acknowledged body (in accordance with ISO/IEC 17021) and where the IQC scheme forms an integral part of the quality management system.

In case the supplier is not in possession of any product certificate (issued by Kiwa or any other accredited certification body), the frequency is increased to 3 visits for the duration of one year.

The audit program on site shall cover at least:

- the product requirements;
- the production process;
- the suppliers IQC scheme and the results obtained from inspections carried out by the supplier;
- the correct way of marking certified products;
- compliance with required procedures;
- handling complaints about products delivered.

For suppliers with a private label certificate the frequency of audits amounts to one audit per year. These audits are conducted at the site of the private label certificate holder. The audits are conducted at the site of private label holder and focussed on the aspects inserted in the IQC scheme and the results of the control performed by the private label holder. The IQC scheme of the private label holder shall refer to at least:

- the correct way of marking certified products;
- compliance with required procedures for receiving and final inspection;
- the storage of products and goods;
- handling complaints.

The results of each audit shall be recorded by Kiwa in a traceable manner in a report.

8.7 Non conformities

When the certification requirements are not met, measures are taken by Kiwa in accordance with the sanctions policy as written in the Kiwa Regulation for Certification.

The Sanctions Policy is available page on the Kiwa website.

8.8 Report to the Board of Experts

De certification body shall report annually about the performed certification activities.

In this report the following aspects are included:

- mutations in number of issued certificates (granted/withdrawn);
- number of executed audits in relation to the required minimum;
- results of the inspections;
- required measures for established Non-Conformities;
- received complaints about certified products.

9 Titles of standards

9.1 Public law rules

BJZ2011048144
29 juni 2011

Regeling van de Staatssecretaris van
Infrastructuur en Milieu¹

9.2 Standards / normative documents

Number	Title
EN 694	Fire-fighting hoses – Semi-rigid hoses for fixed systems
BRL-K643	Fixed firefighting systems – Hose systems – Hose reels with semi-rigid hose
NEN-EN ISO/IEC 17020	Conformity assessment - General criteria for the operation of various types of bodies performing inspection
NEN-EN ISO/IEC 17021-1	Conformity assessment - Requirements for bodies providing audit and certification of management systems
NEN-EN ISO/IEC 17024	Conformity assessment - General requirements for bodies operating certification of persons
NEN-EN ISO/IEC 17025	General requirements for the competence of testing and calibration laboratories
NEN-EN ISO/IEC 17065	Conformity assessment - Requirements for bodies certifying products, processes and services

¹ Valid from 1 July 2017

I Model certificate (example)

	Product certificate KXXXXXX/OX		
	Issued		
	Replaces		
	Page	1 of 1	
CERTIFICATE	Name product		
	STATEMENT BY KIWA With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by		
	Name customer		
	as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline		
	BRL-xxxx "xxxxxxxxxxxxxxxxxxxxxxxx" dated [dd-mm-yyyy] inclusive amendment sheet dated dd-mm-yyyy.		
	Name Director Kiwa		
	Publication of this certificate is allowed. Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.		
Kiwa Nederland B.V. Sir Winston Churchilllaan 273 P.O.Box 70 2280 AB RUISWIJK The Netherlands Tel. +31 88 998 44 00 Fax +31 88 998 44 20 info@kiwa.nl www.kiwa.nl	Company Name customer Address customer Phone number Fax number www. Email		
	140610		
		<table border="1"><tr><td>Certification process consists of initial and regular assessment of:<ul style="list-style-type: none">• quality system• product</td></tr></table>	Certification process consists of initial and regular assessment of: <ul style="list-style-type: none">• quality system• product
Certification process consists of initial and regular assessment of: <ul style="list-style-type: none">• quality system• product			

II Model IQC-scheme (example)

Inspection subjects	Inspection aspects	Inspection method	Inspection frequency	Inspection registration
Raw materials or materials supplied: <ul style="list-style-type: none"> • incoming goods inspection raw materials • incoming goods inspection semi-finished products 				
Production process, production equipment, plant: <ul style="list-style-type: none"> • procedures • working instructions • equipment • material • surface 				
Finished-products				
Measuring and testing equipment <ul style="list-style-type: none"> • measuring equipment • calibration 				
Logistics				