



## Product certificate K-0221129-1

Issued 2024-11-15

Replaces -

Page 1 of 2

### Underground fire hydrants

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### E. Hawle Armaturenwerke GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation

**BRL-K614:** "Fire hydrants", dated 2018-03-06.

which covers the requirements of:

**EN 14339:2005** Underground fire hydrants

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

E. Hawle Armaturenwerke GmbH  
Wagrainer Straße 13  
4840 VÖCKLABRUCK  
Austria  
Tel. +43 7672/725760  
[hawle@hawle.at](mailto:hawle@hawle.at)  
[www.hawle.com](http://www.hawle.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Fire Hydrants

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate.

#### Underground Fire Hydrant

Type of product: Chamber Hydrant No.5025<sup>1</sup>

Size inlet DN 100

Size outlet DN 80

Pressure PN 16

### TOXICOLOGICAL REQUIREMENTS

The toxicological requirements for products coming into contact with drinking water are laid down in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulation materials and chemicals for drinking water and warm tap water supply; published in the Government Gazette).

This product has not been evaluated according to above mentioned regulation.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA".

Place of the mark: on the body or identification plate.

Compulsory specifications

For underground and pillar hydrants:

- Indication of direction of opening;
- Number of turns required to start the flow and for full opening;
- Indication of DN;
- Indication of PN;
- Name or logo of the manufacturer;
- Data or code indicating the year of production;
- Reference to the applicable standard (NEN-EN 14339);
- Loose obturator.

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

Application and use

The hydrants are intended for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 30°C.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- E. Hawle Armaturenwerke GmbH

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.

---

<sup>1</sup> Provided that materials including lubricants in contact with water intended for human consumption comply with the National Regulations.