



## Product certificate K107128/01

Issued 2021-01-01

Replaces -

Page 1 of 2

### 4AQUA OSM 96

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### AQUACARE EUROPE B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with the Kiwa Guideline BRL-K15003 "Evaluation Guideline for the Kiwa product certificate for products used for treatment and/or production of drinking water" d.d. 25-10-2016.

Ron Schepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

AQUACARE EUROPE B.V.  
Graaf Van Solmsweg 58  
5205 CC 'S-HERTOGENBOSCH  
The Netherlands  
Tel. +31(0)73 624 71 71  
[info@aquacare.nl](mailto:info@aquacare.nl)  
[www.aquacareeurope.com](http://www.aquacareeurope.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## 4AQUA OSM 96

---

### PRODUCT SPECIFICATION

This certificate covers the product '4AQUA OSM 96' antiscalant.

### PRODUCT REQUIREMENTS

The product as described in this certificate complies with BRL K15003, including the requirements as specified in NEN-EN 15040: Chemicals used for treatment of water intended for human consumption – Antiscalants for membranes – Phosphonic acids and salts.

### FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects. The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

### MARKING


Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "4AQUA OSM 96";
- "K107128"

### APPLICATION AND USE

'4AQUA OSM 96' is an antiscalant for membrane systems for the preparation of water intended for human consumption.

The maximum dosage of '4AQUA OSM 96' to feedwater is 3 mg/l at maximum.

### REMAINING CONDITIONS

Not applicable.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- AQUACARE EUROPE B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting [www.kiwa.nl](http://www.kiwa.nl).