



## Product certificate K108057/01

Issued 2021-08-01

Replaces -

Page 1 of 3

### Geberit FlowFit PPSU Fittings

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Geberit International AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 G "Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water" dated 13 March 2018

Ron Scheepers  
Kiwa

*This product certificate is only valid in combination with a Kiwa certified plastics piping system.  
Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)



#### Company

Geberit International AG  
Schachenstrasse 77  
8645 JONA  
Postfach 1575  
8640 RAPPERSWIL  
Switzerland  
Tel. +41 (0)55 221 61 11  
info.nl@geberit.com  
[www.geberit.com](http://www.geberit.com)



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Geberit FlowFit PPSU Fittings

### TECHNICAL SPECIFICATION

#### Subject

Geberit FlowFit PPSU Fittings

#### Product characteristics

The product complies to BRL K536-G Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water.

#### Specification

The fittings are suitable for the pipe dimensions stated in the table below

Nominal outside diameter (mm)	Wall thickness (mm)	Minimum wall thickness aluminum layer (mm)	
		Coils Flex pipes	Rods Straight pipe
16	2,0	0,18	0,44
20	2,0	0,28	0,44
25	2,5	0,32	0,47
32	2,8	0,47	0,47
40	3,0	-	0,57
50	3,8	-	0,65
63	4,0	-	0,75
75	4,6	-	1,19

Colour fittings: black with metal press bridle and (before pressing) blue plastic clamping jaw for diameter 16 to 40 mm and orange for diameter 50 to 75 mm.

#### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:





- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

#### Fittings

The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK**\* or **KK**\* (if not possible **KIWA**  only on the smallest packaging unit)\*\*;
- Kiwa (if not possible Kiwa only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.


Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

## Geberit FlowFit PPSU Fittings

---

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** 
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible on every packaging.

\*) for small fittings marking with only KK is permitted.

\*\*) only after approval by Kiwa.

### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### APPLICATION AND USE

The products are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of ISO 10508 and an allowable working pressure of maximum 8/10 bar.

### RECOMMENDATIONS FOR USERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.