



Technical-approval-with-product certificate K108097-2

Issued 2024-11-15

Replaces K108097/01

Page 1 of 3

Geberit FlowFit system

STATEMENT BY KIWA

With this (technical-approval-with-)product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Geberit International AG

as specified in this (technical-approval-with-)product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K536 G " Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water" dated 15 December 2011, inclusive amendment sheet dated 13 March 2018.

Within the framework of this (technical-approval-with-)product certificate Kiwa does not impose any inspections with regard to the production of other parts of the (product), nor the manufacturing of the (product) itself.

Ron Scheepers
Kiwa

This product certificate is only valid in combination with a Kiwa certified plastics piping system.

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

284150610

CERTIFICATE

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.com



Company

Geberit International AG
Schachenstrasse 77
8645 JONA
Postfach 1575
8640 RAPPERSWIL
Switzerland
Tel. +41 (0)55 221 61 11
info.nl@geberit.com
www.geberit.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Geberit FlowFit system

TECHNICAL SPECIFICATION

Subject

Geberit FlowFit system

Product characteristics

The product complies to BRL K536-G Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water.

The system consists of:

- Geberit Pipes, PE-RT type 2/Al/PE-RT type 2, specified as FlowFit pipes, manufactured by Geberit International AG (certificate K85158);
- Geberit FlowFit PPSU Fittings manufactured by Geberit International AG (certificate K108057).
- Geberit FlowFit Metal Fittings manufactured by Geberit International AG (certificate K108563);

Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)	Minimum wall thickness aluminum layer (mm)	
		Coils Flex pipes	Rods Straight pipe
16	2,0	0,18	0,44
20	2,0	0,28	0,44
25	2,5	0,32	0,47
32	2,8	0,47	0,47
40	3,0	-	0,57
50	3,8	-	0,65
63	4,0	-	0,75
75	4,6	-	1,19

Colour:

- Geberit FlowFit Pipes: natural inner layer with not coloured adhesive / silver, metallic or white coloured outer layer.
- Geberit FlowFit PPSU Fittings: black with metal press bridle and (before pressing) blue plastic clamping jaw for diameter 16 to 40 mm and orange for diameter 50 to 75 mm.
- Geberit FlowFit Metal fittings: metal (several colours) with metal press bridle and (before pressing) blue plastic clamping jaw for diameter 16 to 40 mm and orange for diameter 50 to 75 mm.

Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017; ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products shall be marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + class 2/ 10 bar;
- material identification: PE-RT type 2;
- the buildup of the pipe; PE-RT/Al/PE-RT;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter in mm;
- nominal wall thickness of the pipe in mm;
- production code.





The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.

Geberit FlowFit system

*) for smaller diameters permitted by Kiwa.

Fittings


The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK** * or **KK** * (if not possible **KIWA**  only on the smallest packaging unit)**;
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clearly, durable and indelible.

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** 
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clearly, durable and indelible on every packaging.

*) for small fittings marking with only KK is permitted.

***) only after approval by Kiwa.

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The medium pipes and fittings are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of NEN-ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR USERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.