

## Product certificate K108611

Issued 2021-07-15

Replaces -

Page 1 of 2

### Ball Valve

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Caleffi S.p.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-BRL-K604 "Stop- and connection cocks" dated 12-01-2021.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

2871180711

#### Kiwa Nederland B.V.

Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands  
Tel. +31 88 998 33 93  
Fax +31 88 998 34 94  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Caleffi S.p.A.  
S.R. 229.25  
28010 Fontaneto d'Agogna  
Italy  
Tel. +39 0322 849210



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Ball Valve

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Model no.:	Nominal diameter	Designation:
324050	DN20	Ball valve 3/4"M x 3/4"M swivel
324050 LKS	DN20	Ball valve 3/4"M x 3/4"M swivel LKS marking

### Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark 

Place of the mark: body

Compulsory specifications:

- Manufacturer's name or mark on the body
- Nominal size, DN, on the body
- Marking according to EN 13828
- Flow direction

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

Stop- and connecting cocks are designed to be used in tap water installations with a maximum working pressure of 1000 kPa and a water temperature with a maximum of 65 °C. Using the products in water installations with a water temperature up to 90°C is possible. However, this may influence the durability of some parts and the contact temperature of the operation handle.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Caleffi S.p.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.