



Product certificate K109509/01

Issued 2021-12-15

Replaces -

Page 1 of 2

Copper tubes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Serravalle Copper Tubes S.r.l.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K761 "Copper tubes provided with an external covering " D.D. 01-10-2018

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Serravalle Copper Tubes S.r.l.
via Cassano 113
15069 SERRAVALLE SCRIVIA
Italy
Tel. +39(0)14309235
info-plumbing@sctubes.com
www.sctubes.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Copper tubes

Copper tubes according guideline BRL-K761 "Copper tubes provided with an external covering"

Annealed (R220)

10x1 mm
12x1 mm
15x1 mm
18x1 mm
22x1 mm
22x1,1 mm

all provided with an external
finishing layer of plasticized
PVC

Technical specification

Copper tubes according guideline K760 and EN 1057 "copper tubes"
Kiwa certificate K104166

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

Marking

The Kiwa®-mark products are marked with the word mark "KIWA"



Place of the mark: on each 50 cm on the outside of the tube.

*) for small fittings marking with only KK is permitted

Compulsory specifications:

- Dimensions of the tube
- K109509
- Production period
- SCT – EN1057 (Od x WT) (hardness / marking) KIWA KK (quarter/year)

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Serravalle Copper Tubes S.r.l.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.