



Product certificate **K109778/02**

Issued 2022-10-15

Replaces K109778/01

Page 1 of 2

Thermostatic Regulating valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Caleffi S.P.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline **BRL-K14003** "Thermostatic Regulating Valves" d.d. 2020-08-16.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Caleffi S.P.A.
S.R. 229 25
28010 FONTANETO D'AGOGNA (NO)
Italy
Tel. +39 0322 8491
Fax +39 0322 863 305
info@caleffi.it
www.caleffi.it



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Thermostatic Regulating valves

TECHNICAL SPECIFICATION

model 11644* – ½"
model 11645* – ¾"
model 11641* – DN15
model 11642* – DN 22

Remark

The specified products have not been assessed for compliance with all Hygienic Aspects as inserted in the Dutch Drinking Water Decree and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Regulation materials and chemicals drinking water and warm tap water supply) as yet.

APPLICATION AND USE

Thermostatic Regulating Valves are intended for application in circulation systems in tap water installations with a static water pressure of maximum 1000 kPa and a maximum water temperature of 90°C.

After regulating a pre-adjusted minimum temperature upstream will be maintained with conservation of the hydraulic balance.

Marking

The valves shall be marked with the Wordmark KIWA on the outside of the valve.

COMPULSORY MARKING

- On the body:
direction of flow;
nominal diameter (DN);
manufacturers mark.
- On the compression nut of the compression fitting (if applicable)
manufacturers mark;
production code;
nominal size.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Caleffi S.P.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.