



Product certificate K11924/05

Issued 2020-08-01
Replaces K11924/04
Page 1 of 2

X-Flow Membrane Filtration Elements

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

X-Flow B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with the Regeling materialen en chemicaliën drink- en warm tapwatervoorziening dated 01-07-2017 (Materials and chemicals in the supply of drinking water and warm tap water Regulation).

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

X-Flow B.V.
Marssteden 50
7547 TC ENSCHEDE
The Netherlands
P.O. Box 739
7500 AS ENSCHEDE
Tel. +31(0)534287350
xflow@pentair.com
www.x-flow.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

X-Flow Membrane Filtration Elements

PRODUCT SPECIFICATION

This certificate covers the element types S-30, S-150, S-225, XIGA, XIGA HP, AquaFlex, AquaFlex HP, SeaGuard, SeaGuard HP, SeaFlex HP, HFW 1000, HFs nano, HFc nano, Hfe nano and UFC.

The X-Flow membrane filtration elements are available with membrane filtration surfaces of 20, 27, 40, 46, 55 or 64 m².

Fitness for contact with drinking water

The products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"), published in the Government Gazette).


These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING


Design of the required Kiwa certification mark:

- "KIWA ", in ink or seal.

Location of the mark:

- On the product and/or on the packaging.

Mandatory marks:

- "KIWA ";
- "X-Flow membrane filtration elements";
- "K11924".

APPLICATION AND USE

The X-Flow membrane filtration elements are used in the drinking water production for filtration.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- X-Flow B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting www.kiwa.nl.