

Product certificate K13948/07

Issued 2023-10-15

Replaces K13948/06

Page 1 of 3

PE-X pipes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Multilayer Pipe Company Sp. z o.o.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 D "Plastics piping systems of PE-X intended for the transport of cold and heated drinking water" dated 15-12-2011 inclusive amendment sheet dated 10-03-2015.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Multilayer Pipe Company Sp. z o.o.
Pecz 59
57-100 STRZELIN
Poland
Tel. 71 3957000
mpc@mpc.pl
www.mpc.pl



Certification process
consists of initial and
regular assessment of:

- quality system
- product

PE-X pipes

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

PE-Xc pipes, colour natural according to BRL-K 536 part D: Plastics piping systems of PE-X intended for the transport of cold and heated drinking water.

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)
16	2,2
20	2,8
25	3,5

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.



The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The products are marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + Class 2/ 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PE-Xc;
- the build up of the pipe; i.e. PE-Xc;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

Location of the marks: on every pipe at intervals of not more than 2 m.

The realization of the marks is as follows: clear durable and indelible.

*) for smaller diameters permitted by Kiwa.

APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar. used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

PE-X pipes

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Multilayer Pipe Company Sp. z o.o.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.