



Product certificate K21085/03

Issued 2019-01-01

Replaces K21085/02

Page 1 of 2

Non return valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Pittway Sàrl

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K602: "Valves and other accessories for drinking water transport and drinking water distribution system dated 01-02-2012.

which covers the requirements of

EN 1074-3: 2000: "Valves for water supply – Fitness for purpose requirements and appropriate verification tests – Part 3: check valves"

Luc Leroy
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Pittway Sàrl
ACS-ECC EMEA
Z.A. La Piece 16
CH-1180 ROLLE
Switzerland
Phone +43 (0)21 695 30 00

Manufacturer
Ademco 1 GmbH
Hardhofweg
D-74821 Mosbach
Germany
Phone +49 6261 810
Fax +49 626181393
www.homecomfort.resideo.com/europe

Representative
Ademco 1 B.V.
Entrée 258
1101 EA Amsterdam Z.O.
Netherlands
Phone +31 20-5656292
Fax +31 20 2056390
<https://homecomfort.resideo.com/nl>

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Non return valves

Technical specification

The products mentioned below belong to this certificate

RV 283

DN 65

DN 80

DN 100

DN 125

DN 150

Application and use

Non return valves are designed to, both underground as above ground, be used in pipes for drinking water or raw material for drinking water, with a maximum medium temperature of 30 °C. They prevent backflow.

Toxicology

The specified products were not yet assessed for compliance with all aspects as inserted in the "Drinkwaterbesluit" and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K646/03.

Marking

The products are marked with the wordmark "KIWA".

Place of the mark:

- on the body or specification plate

Compulsory specifications:

- name or mark of manufacturer: on the body or specification plate;
- direction of flow on the body
- identification of the shell material(s): on the body or specification plate;
- nominal size "DN ...": on the body or specification plate;
- nominal working pressure "PN ...": on the body or specification plate;
- identification of the year of manufacture: on the body or specification plate;
- number of the relevant part of the EN1074: on the body or specification plate.

Remark:

Specification plate must bear at least the manufacturers mark and the wordmark "KIWA".

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Pittway Sàrl
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.