



Product certificate K21115/11

Issued 2024-02-15

Replaces K21115/10

Page 1 of 3

Connecting cocks

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

VA Albertoni s.r.l.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K604 "Stop- and connecting cocks" dated 2022-01-07.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

VA Albertoni s.r.l.
Via S. Rita 34
28024 GOZZANO
Italy
Tel. +39 322 914800
www.va-albertoni.it



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Connecting cocks

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate;

| Article number | Connecting ends | Finish |
|----------------|--|---------------|
| EDAL 103694 G | G1/2" x G3/8" | brass |
| EDAL 106594 G | G1/2" x 10 mm compression fitting | brass |
| EDAL 4468941 | G1/2" x 10 mm compression fitting | chrome plated |
| EDAL 002 | G1/2" x 10 mm compression fitting | brass |
| C566294KW | G1/2" x 10 mm compression fitting | chrome plated |
| D729694 | G1/2" x 10 mm compression fitting | chrome plated |
| EDAL 003 | G1/2" x 10 mm compression fitting | chrome plated |
| EDAL 004 | G1/2" x G3/8" | brass |
| EDAL 018 | R1/2" x G3/8" connection for concealed cistern | brass |
| D102281 | G3/8" x 12 mm compression fitting | chrome plated |
| ELIV0001 | G1/2" x 10 mm compression fitting | brass |
| AGG106384SD | G1/2" x 10 mm | brass |
| ESIAMP02 | G3/8" x G3/8" | brass |
| EOL0004 | G1/2" x G3/8" | brass |
| ERAM0001 | G1/2" x G3/8" | chrome plated |

Connecting cocks

Fitness for contact with drinking water



These products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The products shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "Kiwa ", the abbreviated word mark "KK" or .

Place of the mark: • on the body.

Compulsory specifications:

- manufacturers mark "VA", on the body and compression fitting (if applicable);
- indication for the direction of flow, on the body (if applicable);
- nominal size: "DN", on the body and compression fitting (if applicable).

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Connecting cocks are designed to shut off, if desired, temporarily, conduit pipes of drinking water installations intended for transporting drinking water with a maximum pressure of 1000 kPa and a water temperature with a maximum of 65°C. Using the products in water installations with a water temperature up to 90°C is possible. However, this may influence the durability of some parts and the contact temperature of the operation handle.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- VA Albertoni s.r.l.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.