



Product certificate K23584/07

Issued 2022-02-01

Replaces K23584/06

Page 1 of 2

Oyster fittings

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Conex Universal Ltd.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K640 "Fittings to be tightened with matching compression tool, compression- and push fit fittings as part of appliances and installations", dated 02-10-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Conex Universal Ltd.
Vantage Point The Pensnett Estate 95
DY67FT KINGSWINFORD WEST MIDLANDS
United Kingdom of Great Britain and Northern Ireland
Tel. +44 (0)121 5572831
technical@ibpgroup.com
www.IBPConex.co.uk



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Oyster fittings

PRODUCT SPECIFICATION

The products mentioned below belong to this -product certificate

Converter fittings

12 x $\frac{3}{8}$ "
12 x $\frac{1}{2}$ "
15 x $\frac{1}{2}$ "
18 x $\frac{3}{4}$ "
22 x $\frac{3}{4}$ "
22 x 1"
28 x 1"

Fitness for contact with drinking water





This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA"  or, on very small fittings only, the abbreviated word mark  or  or  or KK.

Place of the mark: on the fitting.

Compulsory specifications:

- name or mark of manufacturer: on the fitting;
- production date or code.

It is recommended to mark the product with the connecting size(s) of the connecting end(s).

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The OYSTER Fittings to be tightened with matching compression tool, compression- and push fit fittings as part of an appliance or installation are designed to connect copper pipes, according to the Kiwa evaluation guideline BRL-K760, in tap water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Conex Universal Ltd.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.