



## Product certificate K5073/05

Issued 2021-01-15

Replaces K5073/04

Page 1 of 3

### Pipes of unplasticised PVC

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Wavin Nederland B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K17301 "Leidingsystemen van PVC voor transport van drinkwater en ruw water" dated 15-09-2017.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

**Kiwa Nederland B.V.**  
Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
Wavin Nederland B.V.  
J C Kellerlaan 8  
7772 SG HARDENBERG  
invoice.nl@wavin.com  
J C Kellerlaan 8  
7772 SG HARDENBERG  
Tel. +31 (0)523-288911  
info@wavin.nl  
[www.wavin.nl](http://www.wavin.nl)



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Pipes of unplasticised PVC

## PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Nominal outside diameter (mm)	Class					
	5	6,3	8	10	12,5	16
16				x	x	x
20				x	x	x
25				x	x	x
32				x	x	x
40		x		x	x	x
50		x	x	x	x	x
63	x	x	x	x	x	x
75	x	x	x	x	x	x
90	x	x	x	x	x	x
110	x	x	x	x	x	x
125	x	x	x	x	x	x
140		x			x	x
160	x	x	x	x	x	x
180		x	x	x	x	x
200	x	x	x	x	x	x
225		x		x	x	
250	x	x	x	x	x	
280		x		x	x	
315	x	x	x	x	x	
355		x	x	x	x	
400		x	x	x	x	
450		x				
500		x	x	x	x	
630		x	x	x		

## Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:


- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

## MARKING

De fittings shall be marked with the Kiwa®-mark

The minimum required marking on the products shall be:

- Word mark **KIWA** ;
- Industrial trade mark;
- Nominal diameter and wall thickness in mm;
- Material identification: PVC-U;
- Nominal pressure (PN);
- Production period or production code.

The realisation of the marks is as follows: clearly and indelible.

## APPLICATION AND USE

## Pipes of unplasticised PVC

---

The products are intended for PVC-piping systems for the transport of drinking water and raw water with a maximum temperature of 45°C.

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Wavin Nederland B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.