



CERTIFICATE

Product certificate K6159/05



Issued 2024-01-15

Replaces K6159/04

Page 1 of 3

Non-return valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Socla SAS

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

BRL-K602: "Valves, control valves and non-return valves for drinking water transport and drinking water distribution systems" dated 2018-09-04,

which covers the requirements of

NEN-EN 1074-3:2000: Valves for water supply – Fitness for purpose requirements and appropriate verification tests – Part 3: Check valves.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

NL.Kiwa.info@Kiwa.com

www.kiwa.nl

Company

Socla SAS

365 Rue du Lt. Putier

71530 VIREY-LE-GRAND

France

Tel. +33 3 85974200

www.socla.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Non-return valves

TECHNICAL SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate:

<u>type CNF F.223</u>	<u>type 402:</u>	<u>type 402B:</u>	<u>type 402 WG</u>	<u>Type 402 BWG</u>
Ref. 2890K DN 15 Ref. 2891K DN 20 Ref. 2892K DN 25 Ref. 2893K DN 32 Ref. 2894K DN 40 Ref. 2895K DN 50	Ref. 2281 DN 40 Ref. 2282 DN 50 Ref. 2283 DN 65 Ref. 2284 DN 80 Ref. 2285 DN 100 Ref. 2226 DN 125 Ref. 2227 DN 150 Ref. 2229 DN 200 Ref. 2230 DN 250 Ref. 2231 DN 300 Ref. 2232 DN 350 Ref. 2233 DN 400 Ref. 2235 DN 500	Ref. 2351 DN 50 Ref. 2353 DN 65 Ref. 2354 DN 80 Ref. 2355 DN 100 Ref. 2226B DN 125 Ref. 2227B DN 150 Ref. 2229B DN 200 Ref. 2230B DN 250 Ref. 2231B DN 300 Ref. 2232B DN 350 Ref. 2233B DN 400 Ref. 2235B DN 500	Ref. 2281IE DN 40 Ref. 2282IE DN 50 Ref. 2283IE DN 65 Ref. 2284IE DN 80 Ref. 2385IE DN 100 Ref. 2226IE DN 125 Ref. 2227IE DN 150 Ref. 2229IE DN 200 Ref. 2230IE DN 250 Ref. 2231IE DN 300 Ref. 2232IE DN 350 Ref. 2233IE DN 400 Ref. 2235IE DN 500	Ref. 2282BIE DN 50 Ref. 2283BIE DN 65 Ref. 2284BIE DN 80 Ref. 2285BIE DN 100 Ref. 2226BIE DN 125 Ref. 2227BIE DN 150 Ref. 2229BIE DN 200 Ref. 2230BIE DN 250 Ref. 2231BIE DN 300 Ref. 2232BIE DN 350 Ref. 2233BIE DN 400

FITNESS FOR CONTACT MET DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

APPLICATION AND USE

The products are intended for use, above and below ground, as/in or connected to drinking water transport and drinking water distributions system supply lines intended for human consumption with a maximum medium temperature of 30 °C.

Non-return valves

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" 

Place of the mark: on the body or identification plate.

Additional compulsory marking:

- DN identification;
- PN identification;
- Identification of the manufacturer;
- Identification of the year of manufacture;
- identification of the shell material(s);
- Identification of the applicable standard part: EN 1074-3;
- Identification flow direction.

Method of marking as follows:

- indelible
- visible after assembly

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Socla SAS

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.