



Product certificate K6250/11

Issued 2024-10-01

Replaces K6250/10

Page 1 of 3

Float valves for cisterns

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Geberit International AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K615 "Float operated valves for flushing cisterns" dated 15-09-2019,

which covers the requirements of

NEN-EN 14124: 2004 "Inlet valves for flushing cisterns with internal overflow".

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Geberit International AG
Schachenstrasse 77
CH-8645 JONA
Switzerland
Tel. +41 (0) 55 221 63 00
info@geberit.com
www.geberit.com

Supplier

Geberit B.V.
Fultonbaan 15
3439 NE NIEUWEGEIN
The Netherlands
Tel. +31 30 605 7700
info.nl@geberit.com
www.geberit.nl



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Float valves for cisterns

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate.

The indicated types are intended for connection in a (built-in) cistern, unless stated otherwise.

Float valves in the following types:

1. Model Typ 360

Float valve with bottom connection with level independent of the working pressure;

- G³/₄"A according to assembly drawing no. 812.217.00.0;
- G¹/₂"A according to assembly drawing no. 812.218.0.0.

2. Model Typ 380

Float valve with side connection with level independent of the working pressure;

- G³/₄"A according to assembly drawing no. 821.033.0.0;
- G¹/₂"A according to assembly drawing no. 821.040.00.0.

The float valve may be supplied with a Kiwa-certified flexible connection pipe (according to BRL-K622) with PBT nipple, no. 883.650.93.0, according to assembly drawing no. 821.065.00.0.

3. Model Typ 383

Float valve with side connection with level independent of the working pressure;

- G³/₄"A according to assembly drawing no. 1005410138, part no. 828.320.00.0, 898.573.00.0, 898.041.00.0;
- G³/₄"A according to assembly drawing no. 20286039, part no. 828.778.00.0.

The float valve may be supplied with a Kiwa-certified flexible connection pipe (according to BRL-K622) with PBT nipple, no. 828.078, according to assembly drawing no. 1005410138.

Float valves for cisterns

Fitness for contact with drinking water



This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ", or .

Place of the mark:

- on the body.

Compulsory specifications:

- manufacturer name or logo;
- reference to European Standard EN14124;
- acoustical group (if applicable).

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

Float operated valves are intended for use as filling valves for WC flushing cisterns, and designed for connection to potable water installations with a maximum water temperature of 30 °C and a maximum working pressure of 1000 kPa.

The float operated valves, intended for use as filling valves for flushing cisterns:

- are designed with an adjustment-device which guarantees the filling of the flushing cistern to a water level as indicated by the producer;
- shall open, with a decrease of the water level in the cistern of no more than 30 mm.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.