



Product certificate K7303/10

Issued 2022-12-01

Replaces K7303/09

Page 1 of 2

Stainless steel and copper Press fittings

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Geberit International AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K774 "Compression fittings to tighten with matching clamping device" dated 02-10-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Geberit International AG
Schachenstrasse 77
CH-8645 JONA
Switzerland
Tel. +41 (0) 55 221 63 00
info@geberit.com
www.geberit.com



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Stainless steel and copper Press fittings

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

General

Stainless steel and copper press fittings in accordance with BRL-K774 "Compression fittings to tight with matching tightening apparatus".

Additional specifications

Stainless steel press fittings in the diameters 15 mm up to and including 108 mm. Copper press fittings in the diameters 12 mm up to and including 108 mm. The range of approved fittings consists of Tee pieces, reducers, elbows, etc. for which a description is given in BRL-K774 of the types that are preferred.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government





Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.


MARKING

The Kiwa®-mark products are marked with the word mark "KIWA"  or, on very small fittings only, the abbreviated word mark  or  or .

The fittings shall be provided with at least the following marks:

- manufacturer's name, trade name; product name or logo;
- nominal diameter.

The marking can also be applied on the package. The smallest packaging unit of the fittings (maximum of 20 pieces per package) shall be provided with at least the following information:

- the word mark "KIWA"  ;
- manufacturer's name or trade name;
- nominal diameter.

The package shall be completely sealed and protected against the penetration of moisture.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The fittings with compression ends are used to make tensile connections in drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90°C. The connections can be made with stainless steel tubes according Kiwa evaluation guideline BRL K762 and/or copper tubes according Kiwa evaluation guideline BRL-K760 in the quality "half-hard" and "hard".

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.