



## Product certificate K7304/07

Issued 2024-08-15

Replaces K7304/06

Page 1 of 2

### Stainless steel pipes

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Geberit International AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K762 "Steel pipes for the transport of drinking water" dated 16-01-2018.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Geberit International AG  
Schachenstrasse 77  
CH-8645 JONA  
Switzerland  
Tel. +41 (0) 55 221 63 00  
info@geberit.com  
www.geberit.com

Geberit BV  
Fultonbaan 15  
3439 NE Nieuwegein  
The Netherlands  
Tel. +31 (0) 30 605 77 00  
info@geberit.com  
www.geberit.nl

Certification process  
consists of initial and  
regular assessment of:

- quality system
- product



## Stainless steel pipes

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate.

Stainless steel and brass compression fittings, in accordance with BRL-K762 "Seamless and welded stainless steel pipes for water installations"

Additional specification

Seamless and welded stainless steel pipes in sizes 15mm x 1,0 mm to 108 x 2.0 mm.

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government

Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA 

Place of the mark:

- on the exterior of the pipe, at maximum intervals of 500 mm.

Compulsory specifications:

- product name or manufacturer designation (Mapress)
- outside diameter
- type of material

Method of marking:

- non erasable;
- visible after installation.

### APPLICATION AND USE

The products are intended to be used in combination with fittings in accordance with BRL K774 "Compression fittings to tighten with matching clamping device " in water installations with a working pressure of up to 1.0 MPa at a temperature of up to 65°C and a maximum water temperature of 90°C for up to 1 hour.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.