



## Product certificate K77270/05

Issued 2022-08-01

Replaces K77270/04

Page 1 of 2

### Nalco® PC-2040T

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Ecolab Europe GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL K15003 "Evaluation Guideline for the Kiwa product certificate for products used for treatment and/or production of drinking water" dated 2016-10-25.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
Ecolab Europe GmbH  
Richtstrasse 7  
8304 WALLISELLEN  
Switzerland  
Tel. +41 (0)44 877 2000  
Fax +41 (0)44 877 2050

**Production location**  
Nalco Saudi Company Ltd.  
Dammam  
2<sup>nd</sup> Industrial City  
Saudi Arabia



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Nalco® PC-2040T

---

### PRODUCT SPECIFICATION

This certificate covers the antiscalant 'Nalco® PC-2040T'. This product is utilized as an antiscalant in thermal desalination systems.

### PRODUCT REQUIREMENTS

The product as described in this certificate complies with BRL K15003, including the requirements as specified in NEN-EN 15039: Chemicals used for treatment of water intended for human consumption – Antiscalants for membranes – Polycarboxylic acids and salts.

### FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects. The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

### MARKING

Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "Nalco® PC-2040T";
- "K77270"

### APPLICATION AND USE

'Nalco® PC-2040T' is used as an antiscalant in thermal desalination systems.

The maximum dosage to the feed water is:

- 20 mg/l for 'Nalco® PC-2040T'.

### REMAINING CONDITIONS

The means for and the way of transportation, storage and packaging have to be in accordance with the directives as given by the consumer, taking into consideration the use of the product (these guidelines are not a part of the hygienic criteria).

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Ecolab Europe GmbH

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.