

## Product certificate K82439/04

Issued 2023-12-15

Replaces K82439/03

Page 1 of 3

### Butterfly valves

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Socla SAS

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

**BRL-K602** "Valves, control valves, and non-return valves for drinking water transport and drinking water distribution systems" dated 04-09-2018,

which covers the requirements of

**NEN-EN 1074-2:2000** "Valves for water supply – Fitness for purpose requirements and appropriate verification tests – Part 2: Isolating valves".

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

**Kiwa Nederland B.V.**  
Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
Socla SAS  
365 Rue du Lt. Putier  
71530 VIREY-LE-GRAND  
France  
Tel. +33 3 85974200  
[www.socla.com](http://www.socla.com)



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Butterfly valves

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

#### Sylax

##### Centering lug PN 10 en PN 16, duurzaamheid 2500 cycli

DN 25  
DN 32/40  
DN 50  
DN 65  
DN 80  
DN 100  
DN 125  
DN 150  
DN 200  
DN 250  
DN 300  
DN 350

##### Centering lugs PN 10 en PN 16

DN 400  
DN 450  
DN 500  
DN 600  
DN 700  
DN 800  
DN 900  
DN 1000

##### Tapped lugs PN 10 en PN 16

DN 32/40  
DN 50  
DN 65  
DN 80  
DN 100  
DN 125  
DN 150  
DN 200  
DN 250  
DN 300  
DN 350  
DN 450  
DN 500  
DN 600

##### Dubbel geflensd PN 10 en PN 16

DN 150  
DN 200  
DN 250  
DN 300  
DN 350  
DN 400  
DN 450  
DN 500  
DN 600  
DN 700  
DN 800  
DN 900  
DN 1000

## Butterfly valves

---

### Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark: "KIWA  "  
Place of the mark: on the body or specification plate.

Compulsory specifications:

- DN identification;
- PN identification;
- Identification of the manufacturer;
- Identification of the year of manufacture;
- identification of the shell material(s);
- Identification of the applicable standard part: EN 1074-2;

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

The products are intended for use, above and below ground, as/in or connected to drinking water transport and drinking water distributions system supply lines intended for human consumption with a maximum medium temperature of 30 °C.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Socla SAS
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.