



## Product certificate K88324/02

Issued 2022-12-01

Replaces K88324/01

Page 1 of 2

### Frost resistant outdoor taps with wall passage

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Geberit International AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline K14001/04, "Sanitaire kranen: buitenkranen met muurdoorvoer" d.d. 2012-02-01.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Geberit International AG  
Bereich Normung & Zertifizierung  
Schachenstrasse 77  
CH-8645 JONA  
Switzerland  
Tel. +41 43-3511200  
[www.geberit.com](http://www.geberit.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Frost resistant outdoor taps with wall passage

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

artikel nr. S8DS100N1G - Geberit 300 Kranen outside tap, forst-proof

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### APPLICATION AND USE

The frost resistant outdoor taps with wall passage are intended for application in drinking water installations with a static water pressure of maximum 1000 kPa, and a maximum water temperature of 30°C. A working pressure of between 100 and 500 kPa is recommended for proper operation of frost-resistant wall taps.

The frost resistant outdoor taps with wall passage are designed in such a way that drainage of the installation in case of frost is not necessary, due to positioning of the obturator behind or partly in the wall.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA 

Compulsory specifications:

- manufacturer's name or mark; on the wall cover.

Method of marking:

- non-erasable;
- visible after assembly.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Geberit International AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.