



Product certificate K89594/04

Issued 2022-04-01

Replaces K89594/03

Page 1 of 2

Inner hoses to be used for flexible connecting hoses

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

REHAU Industries SE & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14006 "Inner hoses to be used for flexible connecting hoses" dated 01-02-2012.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

REHAU Industries SE & Co. KG
Eltersdorf
Ytterbium 4
91058 ERLANGEN
Germany
Tel. +49 (0) 9131 / 9250
Fax +49 (0) 9283 / 1016
www.rehau.de



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Inner hoses to be used for flexible connecting

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

RAUAQUA PE hose in the following nominal diameters:

- DN6;
- DN8;
- DN10.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ".

Place of the mark: on the hose

Compulsory specifications:

- manufacturer's name or mark;
- type coding of hose;
- digits indicating the month and year of production (MM/YYYY).

Method of marking:

- non-erasable;
- at least every 250 mm of length.

APPLICATION AND USE

The products are intended to be used as inner hoses of flexible connecting hoses as meant in the Kiwa evaluation guideline BRL-K622 "Flexible connecting hoses". These flexible connecting hoses are designed for using in drinking-water installations with a maximum water pressure of 1000 kPa and a maximum water temperature of 70°C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- REHAU Industries SE & Co. KG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.