



Product certificate K95875/03

Issued 2024-01-15

Replaces K95875/02

Page 1 of 2

Insert check valve

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

ZHEJIANG KINGSIR VALVE CO., LTD.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K629 "Backflow protection devices" dated 01-12-2018.

which includes the requirements of

EN 13959:2004: "Anti- pollution check valves - DN 6 to DN 250 inclusive family E, type A, B, C and D".

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

ZHEJIANG KINGSIR VALVE CO., LTD.
NO.10 Fengyu East Road,
Yuhuan ECONOMIC DEVELOPMENT
DISTRICT, ZHEJIANG
China
Tel. +86 576-87427772
kingsir@cn-kingsir.com
www.kingsirvalve.com

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Insert check valve

Technical specification

DN10 – insert check valve – type K7180-1/2"

DN10 – insert check valve – type K718A-1/2"

REMARK

The above listed products were not yet assessed for compliance with all Hygienic Aspects as stated in the Dutch Drinking Water Decree and as outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Regulation on materials and chemicals in drinking water and warm tap water supply), implemented on 19 July 2011.

Application and use

The check valves are intended as backflow prevention devices. Check valves with a nominal diameter less than or equal to 50 mm are intended for application in drinking water installations with a maximum constant water temperature of 65°C and, for a maximum period of 1 hour, a water temperature of 90°C. Check valves with a nominal diameter greater than 50mm are intended for use in a water temperature of up to 65°C. Check valves are intended for application in drinking water installations with a maximum operating pressure of 1000 kPa.

Marking

The Kiwa®-mark products are marked with the abbreviated word mark KK.

Place of the mark: on the housing of the valve.

Compulsory specifications:

- name of manufacturer "Kingsir" on the housing of the valve;
- nominal size: on the housing of the valve;
- indication for direction of flow.

Method of marking:

- non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- ZHEJIANG KINGSIR VALVE CO., LTD.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.