

Product certificate K99118/03

Issued 2024-04-15

Replaces K99118/02

Page 1 of 2

Omyaqua Juraperle Pure

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Eduard Merkle GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K15003 "For the Kiwa product certificate for approval of products used for treatment and or production of drinking water" dated 01-09-2017.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Eduard Merkle GmbH & Co. KG
Altental 6
89143 Blaubeuren
Germany
Tel. +49 7344 960115
www.eduard-merkle.de



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Omyaqua Juraperle Pure

PRODUCT SPECIFICATION

This certificate covers the product 'Omyaqua Juraperle Pure', calcium carbonate with a purity of > 98%.

PRODUCT REQUIREMENTS

The product as described in this certificate complies with BRL-K15003, including the requirements as specified in NEN-EN 1018.

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.
The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate

MARKING


Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "Omyaqua Juraperle Pure";
- "K99118".

APPLICATION AND USE

Omyaqua Juraperle Pure (CaCO_3) is used as filter material in the production of drinking water.

The maximum dosage is 500 mg/l CaCO_3 per liter of drinking water.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- The supplier has delivered in accordance with the agreement;
- The mark and the marking method are correct;
- The products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Eduard Merkle GmbH & Co. KG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.