



Product certificate K-0214622-1

Issued 2024-10-15

Replaces --

Page 1 of 2

Coating systems for drinking water applications

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Chugoku Paints B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K759 [A1] "coating systems for drinking water applications" dated 02-12-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Chugoku Paints B.V.
Sluisweg 12
4794 SW Heijningen
The Netherlands
www.cmpprotectivecoating.com

Production location

Vliegenthart B.V.
Zuiderhavenweg 42
4004 JJ Tiel
The Netherlands



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Coating systems for drinking water applications

PRODUCT SPECIFICATION

The product mentioned below belong to this certificate

CMP CLEANKEEP 5000 E : Red brown, White

Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

This product is marked with Kiwa water mark "KIWA 

Place of the mark: sticker on the outside of the containers, cartons and bags.

Additional compulsory marking:

- Kiwa certificate number.
- Name or logo of the manufacturer/supplier.
- Batch number.
- Production date.
- Maximum shelf life.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

This product is intended for coating of drinking water storage tanks with a metal surface, minimum storage volume of 10 Litres, and a maximum water temperature of 85°C. This coating is not tested for cathodic dis-bonding.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Chugoku Paints B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's guidelines for the proper handling, storage and transport methods.