



## Product certificate K104166/03

Issued 2022-07-15

Replaces K104166/02

Page 1 of 2

### Copper tubes

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Serravalle Copper Tubes S.r.l.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

**BRL-K760 "Koperen buizen" dated 01-12-2018**

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

287180711

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Serravalle Copper Tubes S.r.l.  
via Cassano 113  
Italy  
Tel. +39 14309235  
[www.sctubes.com](http://www.sctubes.com)  
[info-plumbing@sctubes.com](mailto:info-plumbing@sctubes.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Copper tubes

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Copper tubes according guideline BRL-K760 "Copper Tubes" which includes EN 1057 "Copper and copper alloys"

Annealed (R220)	Hard (R290)	Semi-Hard (R250)
10x1 mm	28x1.2	12x1
12x1 mm	35x1.5	15x1
15x1 mm	42x1.5	22x1.1
18x1 mm	54x1.5	28x1.2
22x1 mm		
22x1,1 mm		

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA".

Place of the mark: on each 50 cm on the outside of the tube.

\*) for small fittings marking with only KK is permitted

Compulsory specifications:

- Dimensions of the tube
- Production period
- SCT – EN1057 (Od x WT) (hardness / marking) KIWA KK (quarter/year)

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

The products are meant to be used for domestic networks for hot and cold water

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Serravalle Copper Tubes S.r.l.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.