



Product certificate K110086/02

Issued 2024-06-15

Replaces K110086/01

Page 1 of 2

Coating systems for drinking water applications - Dura-Plate® 146 DW

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Sherwin-Williams Coatings Deutschland GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K759 [A1] "Coating systems for drinking water applications" dated 02-12-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Supplier

Sherwin-Williams Coatings Deutschland GmbH
Rieter Tal 1
71665 VAIHINGEN AN DER ENZ
Germany
Tel. +49 7042 109 4000
pm.kundenservice@sherwin.com
protectiveemea.sherwin-williams.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Coating systems for drinking water application - Dura-Plate® 146 DW

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

Dura-Plate® 146 DW produced in colours: Cream White, Blue, Red Brown, and Beige

Fitness for contact with drinking water.

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink-warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA 

Place of the mark: on the outside of the carton, container, or bag.

Compulsory specifications:

- Factory name and/or registered trademark;
- Production date or code;
- Expiration date;
- Type of indication

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

This coating is suitable for application on metallic surfaces of drinking water installations with a maximum operating temperature of 35 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Sherwin-Williams Coatings Deutschland GmbH
and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's guidelines for the proper storage, transport, processing methods.