



## Product certificate K12327/08

Issued 2023-07-01

Replaces K12327/07

Page 1 of 2

### Coating systems for potable water applications

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### ARKEMA France

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K759 [A1] "Coating systems for potable water applications" dated 02-12-2019.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

287180711

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

ARKEMA France  
Cerdato - SDEP  
Boite Postale 19 0  
27470 SERQUIGNY  
France  
Mme. E. Querat  
Rue d'Estienne d'Orves 420  
F-92705 COLOMBES CEDEX  
France



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Coating systems for potable water applications

---

### PRODUCT SPECIFICATION

The products mentioned below belong to product certificate

Rilsan T Grey 5161 MAC  
Rilsan T Black 7450 AC

### Additional Specifications

Rilsan T Grey 5161 MAC is suitable for application by means of the dip coating method only.

### Additional Specifications – contd.

For all the above mentioned products the use of PRIMGREEN primer is recommended.

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA .

Place of the mark:

On the outside of cartons, containers or bags.

Compulsory specifications:

The maximum shelf life of the products must be specified.

Method of marking:

- Non-erasable with ink;
- Kiwa sticker attached to the product label.

### APPLICATION AND USE

The products are suitable for application as a coating system in potable water installations with a maximum operating temperature of 35 °C. The products are suitable for application in pipelines.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- ARKEMA France

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.