



## Product certificate K5020/05

Issued 2022-04-15

Replaces K5020/04

Page 1 of 3

### Saddles of unplasticized PVC

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Dyka B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K17301 "Piping systems of PVC for the transport of drinking water and raw water" dated 15-09-2017.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
Dyka B.V.  
Produktieweg 7  
8331 LJ STEENWIJK  
Postbus 33  
8330 AA STEENWIJK  
The Netherlands  
Tel. +31 (0)521-534911  
info@dyka.nl  
[www.dyka.nl](http://www.dyka.nl)



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Saddles for PVC-U drinking water pipes

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Saddles for PVC-U drinking water pipes, for piping systems for the transport of drinking water and raw water conform BRL-K17301. The product(s) in the following table(s) belongs to this certificate.

Nominal Diameter (mm)	PN	Screw thread		
	10	Gk ½"	Gk ¾"	Gk 1"
40 (= 63 met inlay)	X	X	X	
50	X	X	X	X
63	X	X	X	X
75	X	X	X	X
90	X	X	X	X
110	X	X	X	X
125	X	X	X	X
160	X	X	X	X
200	X	X	X	X
250	X	X	X	X
315	X	X	X	X

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.



The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

## Saddles for PVC-U drinking water pipes

---

### MARKING

The saddles are provided with at least the following markings:

- **KIWA**  or on smaller products  or **KK**<sup>1)</sup> or **KK**<sup>1)</sup>.
- supplier's name, trade name;
- material identification: PVC-U;
- PN class;
- nominal outside diameter of the connecting pipe in mm;
- production code<sup>2)</sup>;

The markings shall be clear, legible and indelible affixed on each saddle.

- 1 For small fittings marking with kk only is allowed.
- 2 May be displayed if desired in code.

### APPLICATION AND USE

The products are intended to be applied in piping systems: for the transport of drinking water up to a temperature of 20 °C and raw water with a maximum temperature of 45°C

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Dyka B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.