

Product certificate K7295/03

Issued 2013-03-08

Replaces K7295/02

Page 1 of 2


Copper Tubes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Wieland Werke AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K761 "copper tubes".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl



130212

Supplier

Wieland Werke AG
Graf-Arco-Strasse 36
D-89079 Ulm
Duitsland
Tel. +49 7319440
Fax +49 7312772
www.wieland.com
info@wieland.de

**Certification process
consists of initial and
regular surveillance of:**

- quality system
- product

Copper tubes

Technical specification

- Soft copper tubes (R220) in the sizes 12x1.0 mm till 22x1.1 mm
 - Half hard copper tubes (R250)) in the sizes 12x1.0 mm till 54x1.5 mm
 - hard copper tubes (R290)) in the sizes 35x1.5 mm, 42x1.5 mm and 54x1.5 mm
-

Application and use

Copper tubes are intended to be applied in sanitary installations for the transport of warm and cold drinking water

Toxicological requirements

Approval:



This product is approved on the basis of the requirements set in the "Regeling materialen en chemicaliën leidingwatervoorziening" ("Regulation Materials and Chemicals for Drinking Water Supplies"; published in the Staatscourant).

ATA criteria:

The ATA product certification is based on two main criteria. It should permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is laid down in the, for confidentiality reasons, undisclosed appendix to the Kiwa certification agreement. This recipe is not to be changed without prior approval by Kiwa, according to the Kiwa-ATA-approval procedure;
- Specific ATA-product requirements, have been laid down in the appendix to the Kiwa certification agreement. For confidentiality reasons this appendix is not public.

Marking

The Kiwa[®]-mark products are marked with the wordmark "KIWA" together with  or the abbreviated wordmark .

On the tubes, at least once per meter,

- name of the manufacturer and/or trade mark;(Wieland werke)
- production date or –production code;
- product type; (sanco)
- clearly and Non-erasable
- diameter

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Wieland werke AG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.