



Number	63826/06	Replaces	63826/05
Issued	01/07/2024	Scope	AR 137
Contract number	Q96/039	Page	1-2

Product Certificate

## POM gate valves installed in underground PE pipelines

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

### E. Hawle Armaturenwerke GmbH

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 137, for "POM gate valves installed in underground PE pipelines" dated July 2023.

Ron Scheepers  
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.  
Publication of the certificate is allowed.

Kiwa Nederland B.V.  
Sir. Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel.+31 88 998 4400  
info@kiwa.nl  
www.kiwa.nl

**supplier**  
E. Hawle Armaturenwerke GmbH  
Wagrainerstrasse 13  
A-4840 Vöcklabruck  
Austria

<http://www.hawle.at>

T 0043-76722576



Number	63826/06	Replaces	63826/05
Issued	01/07/2024	Scope	AR 137
Contract number	Q96/039	Page	2-2

## POM gate valves installed in underground PE pipelines

---

### PRODUCT SPECIFICATION

#### **2635**

POM-gate valves delivered in black or white

Max. working pressure: 4 bar.

Diameter: 25, 32, 40, 50 and 63 mm.

---

### APPLICATION AND USE

Polyoxymethylene (POM) gate valves installed in underground PE pipelines applied for the transport of gaseous fuels in accordance with the 2<sup>nd</sup> and 3<sup>rd</sup> family as per EN 437. The maximum permissible operating pressure is 4 bar.

---

### MARKING

- GASTEC QA word mark, logo or punch mark
  - Manufacturing mark: E. Hawle Armaturenwerke GmbH
  - Material grade or trade name:
  - Nominal connection measurements and the SDR indication for the PE pipes to be connected
  - Production period, in a code if needs be, which is accessible to the purchaser
  - MOP in bar: 4 bar
- 

### RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.

---