



## Product certificate K-0214061/02

Issued 2024-06-01

Replaces K-0214061/01

Page 1 of 2

### Drinking water system components – health effects according to NSF/ANSI/CAN 61

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the product:

### PE pipes

supplied by

### Plastika Kritis S.A.

as specified in this product certificate and marked with the Kiwa NSF/ANSI 61 in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline Manual K15007 for “drinking water system components – health effects according to NSF/ANSI/CAN 61”, dated 01 May 2024.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Plastika Kritis S.A.  
P Str., Industrial Zone, GR 71408  
P.O. Box 1093  
71110 Iraklion,  
Greece  
  
Tel. +302810-308500  
Fax +30 2810-381328  
e-mail: [info@plastikakritis.com](mailto:info@plastikakritis.com)  
[www.plastikakritis.com](http://www.plastikakritis.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

**Drinking water system components – health effects according to NSF/ANSI/CAN 61****Product specification**

The product mentioned below belongs to this certificate and is intended to be used for transport of drinking water.

Product	Nominal diameter (internal)	Water Contact Temperature	Water Contact Material
PE pipes	25 - 225 mm	Cold water [1]	HDPE
[1] Cold water application: for intended use in continuous exposure to cold water with a maximum end-use temperature of $23 \pm 2$ °C ( $73 \pm 4$ °F).			

**Hygienic aspects***Approval:*

This product is approved on the basis of the requirements set in NSF/ANSI/CAN 61.

*Kiwa NSF/ANSI/CAN 61 criteria:*

The product certification is based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. The recipe is laid down for the confidentiality reasons undisclosed in the appendix to certificate K-0214061. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects, laid down in the appendix to certificate K-0214061. For confidentiality reasons this appendix is not public.

**Marking**

After entering into a Kiwa certification agreement, the certified products shall be clearly and indelibly marked with the certification mark<sup>1)</sup>:



Or words **KIWA NSF/ANSI 61**<sup>1)</sup>

<sup>1)</sup> If not possible the marking shall be on the smallest packaging

**Mandatory marks:**

- “Suppliers name or logo”
- “Product identification (trade name or product type)”
- “Production code”
- “K-0214061”

The realization of the marks as is follows: clearly and indelible.

**RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Plastika Kritis S.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.