

Product certificate
K-0221687-1



Valid from **2026-04-01**

Replaces
Page

1 of 3

Chemical technology for legionella prevention

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

OnicBlue B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

BRL-14010 part 3: "Chemical dosing technology including the management instructions for the product and the installation", dated 2024-05-13.

Wim van Loon
Managing Director Nederland

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.



Chemical technology for legionella prevention

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate:

- Chemical dosing technology OnicBlue Oxiperm PRO OCD 162-5.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" 

Place of the mark: on the device.

Compulsory specifications:

- Factory mark/type or logo;
- Type of connection ends;
- Year of manufacture;
- Material used;
- Working pressure (PN);
- Equipment capacity;
- Ctgb authorization number;
- Serial number

It must be clear to a user and a supervisor that the installed product is certified.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

This BRL focuses on chemical techniques that have been authorized by the Ctgb (Board for the Authorization of Plant Protection Products and Biocides) and are intended for use in collective drinking water and domestic hot water installations as chemical dosing techniques for legionella prevention. With due observance of the management instructions included in the accompanying Attestation, these techniques are considered suitable for plumbing installations with a water pressure of at most 1 MPa (10 bar) and a water temperature specified by the supplier.

Legal preconditions apply to the application of the chemical dosing technique.

Article 20 of the Drinking Water Regulation (Drinkwaterregeling) regulates the conditions for the use of biocides in drinking and domestic hot water installations.

The equipment belonging to the chemical dosing technique can be installed in the system as follows:

In the main supply line of the entire installation;
In the supply line of a part of the installation.

Chemical technology for legionella prevention

RECOMMENDATIONS FOR THE CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- OnicBlue B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.