



Product certificate K101109-4

Issued 2025-03-01

Replaces K101109/03

Page 1 of 3

Heat exchangers

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Daikin Europe NV

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K656: "Heat exchangers intended for the indirect adjustment of the temperature of drinking water" dated 2021-04-16.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

CERTIFICATE

289171015

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.com

Company

Daikin Europe NV
Zandvoordestraat 300
B-8400 OOSTENDE
Belgium
Tel. +32 595 588 99
info@daikineurope.com
www.daikin.europe.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Heat exchangers

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

DHW cylinders for Daikin Altherma products.

Models:

- EKHWSU*;
- EGSAH*;
- EGSAH*;
- EKHWSU(150/200/300)B*

Pressure-less Domestic Hot Water Tanks.

Models:

- EKHWC300Bx, -300PBx
- EKHWC500Bx, -500PBx
- EKHWC500Bx, -500PBx
- EKHWP300Bx, -300PBx
- EKHWP500Bx, -500PBx
- EKHWP54419Bx
- EPS**10P(30/50)**
- EPS**14P(30/50)**
- EHS****P30E*
- EHS****P50E*
- ETS**12P30E*
- ETS**12P50E*
- EBS****P30D*
- EBS****P50D*
- ETS**16P30E*
- ETS**16P50E*
- ELS*12P30E*
- ELS*12P50E*
- ELS**12P30E*
- ELS**12P50E*

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

Heat exchangers

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ,
Place of the mark: on the heat exchanger identification plate or label

Compulsory specifications:

- Trade mark or logo;
- Construction (single-partition/double-partition);
- Type of the connection ends;
- Year of manufacture;
- Primary side working pressure;
- Secondary side working pressure;
- Maximum primary water temperature;
- Maximum secondary water temperature;
- Marking of primary and secondary connection ends.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to be used in hot water installations with a working pressure of maximum 1 MPa (10 bar) and a water temperature of maximum 85 °C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Daikin Europe NV
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.