



Product certificate K13175/06

Issued 2024-01-15

Replaces K13175/05

Page 1 of 2

Check valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

AMFAG S.r.l.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K629 "Anti-pollution check valves - DN6 to DN250, inclusive family E, type A, B, C and D" dated 01-12-2018.

EN 13959:2004: "Anti-pollution check valves - DN 6 to DN 250 inclusive family E, type A, B, C and D".

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
AMFAG S.r.l.
Via G. Falcone 3
46040 CASALOLDO
Italy
Tel. +39 (0)376 732622
logistic@amfagairforce.com
www.amfag.it



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Check valves

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

Article number	Nominal Diameter	Diameter	Depth
AV10	DN6	ø10,4 mm (top) ø9,8 mm (bottom)	10,6 mm
AV14	DN10	ø13,98 mm	15,9 mm
AV15C	DN10	ø14,8 mm	15,9 mm

Fitness for contact with drinking water



This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"), published in the Government Gazette.

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ", or the abbreviated mark .

Place of the mark: on the housing.

Compulsory specifications:

- name or mark of manufacturer: on the housing or the valve;
- nominal size: on the housing or the valve;
- indication for direction of flow.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to be mounted in appliances to serve as part of or as total safety against the backflow of water or other liquids being downward of the stream of this safety device.

The check valves are suitable for application in drinking water installations with a maximum operating pressure of 1000 kPa and a maximum constant water temperature of 65 °C. Occasional occurrences up to 90 °C are permitted for a period of 1 h maximum.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- AMFAG S.r.l.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.