



## Product certificate K20202/04

Issued 2020-08-01  
Replaces K20202/03  
Page 1 of 2

### X-Flow Membrane Filtration Elements

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### X-Flow B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with the Regeling materialen en chemicaliën drink- en warm tapwatervoorziening dated 01-07-2017 (Materials and chemicals in the supply of drinking water and warm tap water Regulation).

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

CERTIFICATE

575711015

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

[info@kiwa.nl](mailto:info@kiwa.nl)

[www.kiwa.nl](http://www.kiwa.nl)

#### Company

X-Flow B.V.

Marssteden 50

7547 TC ENSCHEDE

The Netherlands

P.O. Box 739

7500 AS ENSCHEDE

Tel. +31(0)534287350

[xflow@pentair.com](mailto:xflow@pentair.com)

[www.x-flow.com](http://www.x-flow.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## X-Flow Membrane Filtration Elements

---

### PRODUCT SPECIFICATION

This certificate covers the element type F4385, which is coded with <l><d><m><c>/F4385 where:

<l> = length : 1, 2 or 3 (meters);  
<d> = diameter : 3 or 8 (inch);  
<m> = material : P for PVC;  
<c> = configuration : E for axial or R for radial.

The X-Flow membrane filtration elements are available with membrane filtration surfaces of 1.6, 3.4, 5.2, 9, 19 or 29 m<sup>2</sup>.

### Fitness for contact with drinking water

The products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"), published in the Government Gazette).


These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING


Design of the required Kiwa certification mark:

- "KIWA ", in ink or seal.

Location of the mark:

- On the product and/or on the packaging.

Mandatory marks:

- "KIWA ";
- "X-Flow membrane filtration elements";
- "K20202".

### APPLICATION AND USE

The X-Flow membrane filtration elements are used in the drinking water production for filtration.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- X-Flow B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting [www.kiwa.nl](http://www.kiwa.nl).