

# Certificate

## Product certificate K22875-11



Valid from **2025-09-15** Replaces **K22875-10**  
Page **1 of 3**

## Heat Exchangers

### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

## SWEP International AB

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL K656: "Heat exchangers intended for the indirect adjustment of the temperature of drinking water, dated 2021-08-16.

Wim van Loon  
Managing Director Nederland

Publication of this certificate is allowed.  
Advice: consult [www.kiwa.com](http://www.kiwa.com) in order to ensure that this certificate is still valid.



**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
NL.Kiwa.Info@kiwa.com  
[www.kiwa.com](http://www.kiwa.com)

**SWEP International AB**  
Hjalmar Brantings väg 5  
261 43 LANDSKRONA  
Sweden  
Tel. +46 418400400  
[info@swep.net](mailto:info@swep.net)  
[www.swep.net](http://www.swep.net)

## Heat Exchangers

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

#### BRAZED PLATE HEAT EXCHANGER:

##### Single partition type:

- E5T, IC5T
- E5K
- E5AS, IC5AS
- E5P
- E6T, IC6T
- E8AS
- E8LAS
- 8LAS
- E8T, IC8T
- 10T, IC10T
- 25T, IC25T

##### Double partition type:

- 8DW
- 16DW
- 16NDW
- 35TDW

#### **Fitness for contact with drinking water**

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

#### **MARKING**

The Kiwa®-mark products are marked with the word mark "KIWA ".

Place of the mark: on the identification plate of the heat exchanger.

##### Compulsory specifications:

- Trade mark/type or logo;
- Construction (single-partition/double-partition) ;
- Secondary side wall material used;
- Intended purpose of use of the connection ends;
- Year of manufacture;
- Primary side working pressure;
- Secondary side working pressure;
- Designation of liquid intermediate medium;
- Maximum primary water temperature;
- Maximum secondary water temperature;
- Marking of primary and secondary connection ends.

## Heat Exchangers

---

Method of marking:

- Non-erasable;
- Visible after assembly.

### **APPLICATION AND USE**

The heat exchangers are intended to be used in hot water installations with a working pressure of maximum 1 MPa and a water temperature of maximum 90 °C.

### **RECOMMENDATIONS FOR THE CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- SWEF International AB
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.