

Certificate

Product certificate K23517-10



Valid from **2025-09-15** Replaces **K23517/09**
Page **1 of 2**

Sokalan® PM 15 I

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Solenis Switzerland GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Regeling materialen en chemicaliën drink- en warm tapwatervoorziening dated 01-07-2017 (Materials and chemicals in the supply of drinking water and warm tap water Regulation).

Wim van Loon
Managing Director Nederland

Publication of this certificate is allowed.
Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.



Kiwa Nederland B.V.
Sir Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
NL.Kiwa.Info@kiwa.com
www.kiwa.com

Certificate holder
Solenis Switzerland GmbH
Mühlentalstrasse 38
8200 SCHAFFHAUSEN
Switzerland
Tel. +41 (0) 78 689 71 61
www.solenis.com

Sales Office
Solenis NL
De Corridor 4
3621 ZB BREUKELEN
The Netherlands

Distribution Centre
H. Essers & Zonen
Internationaal Transport NV
Henry Fordlaan 8
Dryport – 14F GENK
Belgium

PRODUCT SPECIFICATION

This certificate covers the antiscalant Sokalan® PM 15 I.

Fitness for contact with drinking water



This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.



MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" / "KIWA ", , KK* or KK*

Place of the mark: On the packaging / On the delivery receipt.

*) for small fittings marking with only KK is permitted

Mandatory marks:

- "KIWA" / "KIWA ", , KK* or KK*
- "Sokalan® PM 15 I";
- "K23517".

Method of marking:

Non-erasable;

visible after assembly.

APPLICATION AND USE

'Sokalan® PM 15 I' is an antiscalant for desalination plants for the preparation of water intended for human consumption, using:

- distillation;
- reversed-osmosis membranes.

The dosage of 'Sokalan® PM 15 I' to feedwater is:

- 10 mg/l at maximum in distillation plants;
- 5 mg/l at maximum in plants using reversed-osmosis membranes

RECOMMENDATIONS FOR THE CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Solenis Switzerland GmbH

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.