



## Product certificate K25503/06

Issued 2024-04-15

Replaces K25503/05

Page 1 of 2

### Backflow protection devices Family C, type A

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Pittway Sàrl

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

**BRL-K648:** "Niet controleerbare terugstroombeveiligingstoestellen, met verschillende drukgebieden - familie C, type A" dated 01-02-2012.

which covers the requirements of

**NEN-EN 14367:** " Non controllable backflow preventer with different pressure zones - Family C, type A".

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

CERTIFICATE

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

[info@kiwa.nl](mailto:info@kiwa.nl)

[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Pittway Sàrl

A3 - ZA La Pièce 6

1180 Rolle

Switzerland

Phone+43 21 695 30 00

#### Manufacturer

Ademco 1 GmbH.

Hardhofweg 40

74821 Mosbach

Germany

Phone +49 6261 810

Fax +49 626181393

[www.homecomfort.resideo.com/europe](http://www.homecomfort.resideo.com/europe)

#### Representative

Ademco 1 B.V.

Entrée 258

1101 EA Amsterdam Z.O.

Netherlands

Phone +31 20-5656292

Phone +31 20 2056390

<https://homecomfort.resideo.com/nl>

Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Backflow protection devices Family C, type A

---

Technical specification

Backflow prevention device family C, type A

CA 295

CA 295 DN 15

---

### Application and use

Non Controllable backflow preventer with different pressure zones – Family C, type A are designed as safety devices for the prevention of contamination in drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 65 °C.

---

### Toxicology

The specified products were not yet assessed for compliance with all aspects as inserted in the “Drinkwaterbesluit” and outlined in the “Regeling materialen en chemicaliën drink- en warm tapwatervoorziening” (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K648/03.

---

### Marking

The products are marked with the Kiwa-mark.

Place of the mark: on the body or the identification plate.

### Compulsory specifications:

name or mark of manufacturer;

- arrow showing direction of flow on the body;
- nominal size (DN);
- nominal pressure (PN);
- class;
- maximum temperature;
- serial number;
- reference to EN 14367;
- reference to family and type.

### Method of marking:

- Non-erasable;
- Visible after installation.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Pittway Sàrl
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.