CERTIFICATE

Product certificate
K41880/04

Issued *2024-02-01*

Replaces *K41880/03*

Page *1 of 3*

Backflow preventers Family C - Type A

STATEMENT BY KIWA
With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Gebr. Kemper GmbH & Co. KG Metallwerke

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K648 “Non controllable backflow preventer with different pressure zones - Family C, type A” dated 01-12-2018

which includes the requirements of

EN 14367:2005 " Non controllable backflow preventer with different pressure zones - Family C, type A"

Ron Scheepers
Kiwa

Publication of this certificate is allowed.
Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

2871/80711

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Gebr. Kemper GmbH & Co. KG
Metallwerke
Harkortstraße 5
57462 OLPE
Germany
Tel. +49 27 61 89 11 75
www.kemper-olpe.de

PRODUCTS
RvA C 002

Certification process consists of initial and regular assessment of:
- **quality system**
- **product**

Backflow preventers Family C - Type A

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Backflow preventer;
Fig. 362 – family C – Type A – DN 15 (class A)
Fig. 362 – family C – Type A – DN 20 (class B)

Backflow preventers Family C - Type A

APPLICATION AND USE

Non controllable backflow preventer with different pressure zones – Family C, type A are designed as safety devices for the prevention of contamination in drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 65 °C.

Hygienic aspects

The specified products were not yet assessed for compliance with all aspects as inserted in the “Drinkwaterbesluit” and outlined in the “Regeling materialen en chemicaliën drink- en warm tapwatervoorziening” (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K648: 2018.

MARKING

The Kiwa®-mark products are marked with the word mark “KIWA”.
Place of the mark:

- on the body

Compulsory specifications:

- Name or mark of manufacturer;
- Arrow showing direction of flow on the body;
- Nominal size (DN);
- Nominal pressure (PN);
- Class;
- Maximum temperature;
- Serial number;
- Reference to EN 14367;
- Reference to family and type

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Gebr. Kemper GmbH & Co. KG Metallwerke

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier’s processing guidelines for the proper storage and transport methods.