



KOMO®

Technical-approval-with product certificate
K43192/03



Issued	2021-05-01	Replaces	K43192/02
Valid until	Indefinite	Dated	2015-12-01
Page	1 of 3		

Quick & Easy System

UPONOR GmbH

STATEMENT BY KIWA

This technical approval-with-product certificate on the basis of BRL 5609 part 2 Pre-insulated flexible plastics piping systems for warm water distribution outside buildings : Products issued on 27 August 2019 by Kiwa, in accordance with the Kiwa Regulation for Certification.

The quality system and the product characteristics belonging to the Quick & Easy System are checked periodically and the performance of the Quick & Easy System in the application as floor heating is assessed. The basic principles for the assessment are checked periodically.

Based on this Kiwa declares that:

- legitimate confidence exists that the by the holder of the technical approval- with-product certificate delivered Quick & Easy System comply with:
 - the technical specifications as laid down in this technical approval-with-product certificate;
 - the product requirements as laid down in this technical approval-with-product certificate, provided that they have been marked the Quick & Easy System with the KOMO®-mark in the manner as indicated in this technical approval-with-product certificate;
- the Quick & Easy System provides the performances as described in this KOMO technical approval-with-product certificate, provided that:
 - the application conditions and technical specifications as described in this KOMO approval-with-product certificate are met;
 - the manufacturing takes place according to the processing methods as laid down in this technical approval-with-product certificate.

Within the framework of this KOMO technical approval-with-product certificate there is no inspections with regard to the production of other parts of the Quick & Easy System or the processing of the Quick & Easy System.

Ron Scheepers
Kiwa

This technical approval-with-product certificate is also included on the KOMO foundation websites: www.komo.nl and www.komo-online.nl.

Users of technical approval-with-product certificate is advised to check whether it is still valid. For this purpose consult the website of Kiwa: www.kiwa.nl.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Certificate holder
UPONOR GmbH
Industriestrasse 56
D-97437 HASSFURT
Germany
Tel. +49 (0)9521 6900
Fax +49 (0)9521 690105
info.de@uponor.com
www.uponor.com



Assessed is:

- Quality system
- Product
- Performance in the application

Periodic control

Quick & Easy System

TECHNICAL SPECIFICATION

Subject

Quick & Easy System

Product characteristics

The product complies to BRL 5609 Pre-insulated flexible plastics piping systems for warm water distribution outside buildings - Part 2:Products.

The system consists of:

- 3-layer PE-Xa Pipes manufactured by Uponor GmbH (certificate K43191);
- Metal Fittings manufactured by Uponor GmbH (certificate K12062).

Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
50	4,6
63	5,8
75	6,8
90	8,2
110	10,0

Colour:

- Pipes: white inside / white outside.
- Fittings:brass

Remarks:

- Metal fittings with a plastics clamp ring of PE-X on the outside are used.
- The joints are made with a special expansion system.

Marking

The products shall be marked with the KOMO® mark.

Pipes

The minimum required marking on the pipes shall be:

- KOMO (or KOMO® word mark) + class DH1/ 6 bar;
- material identification: PE-Xa;
- the build up of the pipe; PE-X/EVOH;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter in mm;
- nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.

Fittings

The minimum required marking on the fittings shall be:

- KOMO (if not possible KOMO only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.



Quick & Easy System

The realization of the marks is as follows: clearly, durable and indelible.

The minimum required marking on the smallest packaging unit of the fitting shall be:

- KOMO (or KOMO® word mark);
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clearly, durable and indelible on every packaging.

Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

PROCESSING

The supplier shall provide installation instructions, approved by Kiwa. A reference to these instructions shall be made at or near the packaging. The instructions are published in the Dutch language and contains at least specific information with regard to storage, transport, processing temperature and construction of the joints.

So-called "combination boilers" are often applied in individual house heating systems. In such boilers, no double separation between drinking water and heating medium exists. A leak in the single separation may result in the heating medium coming into contact with drinking water. Because of this it is important that in case additives are added to the heating medium a Kiwa product certificate for these additives has been issued.

PERFORMANCES

1. The system is oxygen tight.
2. All joints are leak tight and possess sufficient clamp force to resist external influences.

PERFORMANCES OF THE PRODUCTS

The medium pipes and fittings are designed for warm water distribution outside buildings with a lifetime of 30 years at an operating temperature profile according to class DH1 of BRL 5609-2 and an allowable working pressure of maximum 6 bar.

TIPS FOR THE USER

Check on delivery of the products listed under the "technical specification" whether:

- The product(s) and material(s) ordered are delivered in accordance with the agreement you made.
- The brand and the method of marking is correct
- No defects or damage is visible (for example, resulting from the transportation).

If on the basis of the foregoing you decide to proceed to rejection, please contact

- UPONOR GmbH

And if necessary,

- Kiwa Nederland B.V.

Carry out the storage, transport and processing in accordance with the provisions included in this technical-approval-with-product certificate and/or documents of the certificate holder.

