



Product certificate K6113/10

Issued 2024-03-01

Replaces K6113/09

Page 1 of 2

Expansion groups

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Watts Industries France

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K630 "Expansion groups and expansion valves" dated 01-12-2018.

Which includes the requirements of
EN1488: 2000 " Building valves - Expansion groups - Tests and requirements"

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Watts Industries France
Route Nationale 100
80132 HAUTVILLERS-OUVILLE
France
Tel. 322247011
www.wattsindustries.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Expansion groups

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

BI15, ref. 1852558;
Kit BI15, ref. 2252553;
Kit BI 15, ref. 3152989019935.

Fitness for contact with drinking water


This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark KIWA 

Place of the mark: on the body

Compulsory specifications:

- The manufacturers name, trade mark or identification mark;
- The Nominal size, DN;
- The nominal set pressure, P_{nr} ;
- An arrow showing the direction of flow of the supply, on at least one face;
- The month and year manufacture or code relating to the period of manufacturing;
- The acoustic classification;
- The model reference.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Expansion groups in nominal sizes DN 8 up to and including DN 100 are intended to be used in drinking water installations with an upstream pressure of 1,0 MPa and a water temperature of 30 °C for cold water applications and a maximum of 95 °C for hot water applications.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Watts Industries France
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.