



Product certificate K6252/07

Issued 2023-05-01

Replaces K6252/06

Page 1 of 3

Plastic service taps for water

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

E. Hawle Armaturenwerke GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K660: "Plastic service taps for water" dated 01-12-2018.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

E. Hawle Armaturenwerke GmbH
Wagrainer Straße 13
4840 VÖCKLABRUCK
Austria
Tel. +43 7672/725760
hawle@hawle.at
www.hawle.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Plastic service taps for water

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate (delivered in black and white)

connection to the main line	3/4"
connection to the service line	25 mm
flow class	A

connection to the main line	1"
connection to the service line	25 mm
flow class	B

connection to the main line	1"
connection to the service line	1 1/4"
flow class	A

Plastic service taps for water

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA , .

Place of the mark: on the tap body.

Compulsory specifications:

- manufacturer's name and / or registered trademark;
- the outer diameter, in mm, of the associated tube;
- the flow class;
- the connection size of the main line.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Plastic service taps are intended for use in underground connections on PE pipes for drinking water. The pipes to be used must comply with NEN 7116.

The recommended limits for proper operation are a working pressure between 100 and 500 kPa and a water temperature of up to 30 °C. The plastic service taps can be used for tap water applications with a working pressure of up to 1000 kPa.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- E. Hawle Armaturenwerke GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.