



Product certificate K76061-6

Issued 2025-04-01

Replaces K76061/05

Page 1 of 2

Copper tubes provided with an external covering

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

ELVALHALCOR S.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

BRL-K761: "Copper tubes provided with an external covering " dated 01-02-2012,

which covers the requirements of

EN 1057:2006 "Copper and copper alloys – Seamless, round copper tubes for water and gas in sanitary and heating applications".

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.com

Company
ELVALHALCOR S.A.
62nd National Rd Athens-Lamia
32011 OINOFYTA VIOTIAS
Greece
Tel. +302262048111
info@elvalhalcor.com
www.elvalhalcor.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Copper tubes provided with an external covering

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

General

Copper tubes according guideline BRL-K761 "Copper tubes provided with an external covering" which includes "Kiwa-keuringseisen" nr. 57 "Koperen pijpen", and EN 1057 "Koperen buizen".

Additional specification

PVC Soft copper tubes (R220) in the sizes 10x1,0mm,12x1,0mm, 15x1,0 mm, 18x1,0 and 22x1,1mm
[coils of 25 m or 50 m]
Ecutherm/Cutis Soft copper tubes (R220) in the sizes 10x1,0mm,12x1,0mm, 15x1,0 mm, 18x1,0 and 22x1,1mm
[coils of 25 m or 50 m]
PVC or PVC Yellow Half hard copper tubes(R250) in the sizes 10x1,0mm, 12x 1,0mm, 15x1,0mm, 18x 1mm, 22x1,1mm and 28x1,2mm
[straight lengths]
Inner surface cleaning of the tubes:
are annealed or vacublasted.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ". *

Place of the mark: slightly pressed in on each 50 cm on the outside side of the tube.

*) for small fittings marking with only KK is permitted

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are meant to be used for domestic distributing networks for hot and cold water.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- ELVALHALCOR S.A.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.