

Product certificate
K76500-2



Valid from **2025-09-15** Replaces **K76500/01**
Page **1 of 2**

Check valves, family E, type B

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Ankofit Industries B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline:

BRL K629/03: "Anti-pollution check valves - DN 6 to DN 250 inclusive – family E, type A, B, C and D" dated 01-02-2012.

which includes the requirements of

EN 13959:2004: "Anti-pollution check valves - DN 6 to DN 250 inclusive family E, type A, B, C and D".

Wim van Loon
Managing Director Nederland

Publication of this certificate is allowed.
Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.



Check valves, family E, type B

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate:

Artikel nr.	Description
54430	DN15, with compression fitting KF15 x KF15, G1/4" control connections
54431	DN20, with compression fitting KF22 x KF22, G1/4" control connections
54432	DN25, with compression fitting KF28 x KF28, G1/4" control connections

Remarks

The specified products were not yet assessed for compliance with all aspects as inserted in the "Drinkwaterbesluit" and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulations Materials and Chemicals for Drinking Water Supplies -implemented 19 July 2011) as specified in the clause 4.2.1 of the Kiwa evaluation guideline BRL-K629/03.

APPLICATION AND USE

Check valves with a nominal diameter smaller than or equal to 50 mm are intended for application in drinking water installations with a maximum constant temperature of 65°C and with a maximum of one hour with a water temperature of 90° C. Check valves with a nominal diameter larger than 50 mm are intended for water temperatures till 65° C only.

MARKING

The Kiwa[®]-mark products are marked with the word mark "KIWA".

Place of the mark:

- for check valves: on the body (Kiwa)
- for cartridge check valves :on the body and on the insert check valve with letters "EA".

Compulsory specifications:

- Manufacturers mark "BPE3";
- Nominal size (DN) on the body;
- Indication for flow direction;
- On the check valve, the abbreviated word mark 'KK' in a rectangle.

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:
the supplier has delivered in accordance with the agreement;
the mark and the marking method are correct;
the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Ankofit Industries B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.