



Product certificate K82446-2

Issued 2025-04-01

Replaces K82446/01

Page 1 of 3

Butterfly valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

E. Hawle Armaturenwerke GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K602 "Valves and other accessories for drinking water transport and drinking water distribution systems" dated 21-04-2023.

which covers the requirements of

EN 1074/2:2000 "Valves for water supply - Fitness for purpose requirements and appropriate verification tests - Part 2: Isolating valves".

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.com

Company

E. Hawle Armaturenwerke GmbH
Wagrainer Straße 13
4840 Vöcklabruk
Austria
Tel. +43 76 72 72 57 60
hawle@hawle.at
www.hawle.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Butterfly valves

PRODUCT SPECIFICATION

The products mentioned below belong to this certificate

Type 9881 and Type 9881K, PN 10 and PN16, manually operated

DN 150

DN 200

DN 250

DN 300

DN 350

DN 400

DN 450

DN 500

DN 600

DN 700

DN 800

DN 900

DN 1000

DN 1100

DN 1200

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" together , with or the abbreviated word mark. The fittings shall be provided with at least the following marks:

Compulsory specifications:

- name or mark of manufacturer: on the body or specification plate;
- identification of the shell material(s): on the body or specification plate;
- nominal size "DN ...": on the body or specification plate;
- nominal working pressure "PN ...": on the body or specification plate;
- identification of the year of manufacture: on the body or specification plate.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended for use, above and below ground, in drinking water transport and drinking water distributions system supply lines intended for human consumption

Butterfly valves

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- E. Hawle Armaturenwerke GmbH

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.