



Product certificate K91123/03

Issued 2021-08-15

Replaces K91123/02

Page 1 of 2

Lubricants for rubber ring joints

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Brett Martin

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K535 "Lubricants for rubber ring joints", dated 05-10-2017

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Brett Martin
Speedwell Industrial Estate
Stepheson Road, Staveley,
Derbyshire
S43 3JP ENGLAND
United Kingdom of Great Britain and
Northern Ireland
Tel. 1246280000



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Lubricants for rubber ring joints

PRODUCT SPECIFICATION

The products as specified in the table below fulfil the requirements of BRL-K535 "Lubricants for rubber ring joints" and are part of this declaration.

Lubricant
<ul style="list-style-type: none">Brett Martin Pipe Jointing Lubricant Gel

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"); published in the Government Gazette.

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The following marks and indications must be provided on each product and product packaging in a clear, legible and indelible way:

- The name of manufacturer or the deposited trade mark;
- Kiwa (of Kiwa®-word mark) and additionally the Kiwa watermark ;
- Production date or -code;
- Type number of the lubricant;
- Materials of the tubes for which the lubricant is usable;
- The expiry date in an unopened packaging;
- Necessary precautions to provide a good and safe use;

A note on the package that points to the corresponding processing instructions is also sufficient

Method of marking:

- Non-erasable;
- Visible after assembly.

APPLICATION AND USE

The lubricant is intended to be applied during mounting of rubber seals in a piping system of:

- concrete;
- asbestos cement;
- cast iron or steel;
- unplasticised polyvinyl chloride (PVC-U);
- polyethylene (PE), polypropylene (PP);
- fiberglass reinforced elastomers (GVK).

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Brett Martin
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.